

Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

03/08/2022

Permit # 000043488

L-28365


Stanley Crawford Construction

Re: Lot 38 Southern Meadows

To Whom It May Concern:

The top of the finished slab on Lot 38 is found to be 82.72 feet. The building permit shows the minimum floor elevation to be 81 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,


L. Scott Britt
LS 5757