

SCOPE OF WORK JOB DETAILS LIST

1. Update the existing devices to current code compliance, AFCI/GFCI protection.
2. Add TR AFCI/GFCI-protected receptacle to the right of the sink, right of the range/oven, and left of the range/oven for the required by the NEC.
3. Install light over the sink with new switching.
4. Repair the damaged electrical box and device on the sink wall.
5. Label the electrical panel.