

37495



---

**Britt Surveying and Mapping, LLC**  
2086 SW Main Blvd Ste 112 • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

01/09/2019

L-25611

Re: Lot 24 Forest Country Unit 6

K & H Framing

To Whom It May Concern:

The top of the stemwall on lot 24 is found to be at 95.51 feet. The minimum floor elevation for said Lot 24 is 95.5 feet per the plat of record. The lowest adjacent grade is 91.5 feet and the highest adjacent grade is 92.4 feet. All elevations are shown per the plat datum.

Sincerely,

A handwritten signature in blue ink, appearing to read "L. Scott Britt", is written over a faint, circular, textured background.

L. Scott Britt  
LS 5757