



Loft Life Safety PLAN

FIRE EXTINGUISHER CABINETS

PROVIDE 10 LB ABC FIRE EXTINGUISHERS IN ALUM. SEMI-RECESSED WALL CABINETS W/ BREAKAWAY GLASS FRONT PANEL. LOCATE I CABINET AT EACH EXIT DOOR OF EACH SPACE, WITHIN 10 FEET OF THE DOOR ANY OTHER LOCATIONS SHALL BE AS DIRECTED BY THE FIRE MARSHAL AND/OR OWNER.

EXIT ACCESS TRAVEL DISTANCE PER 2010 FBC 1015, TABLE 1015.1 OCCUPANCY - ASSEMBLY: 150 FT. (W/O SPRINKLER SYSTEM)

FIRE DEPARTMENT REQ'D MARKING

PROVIDE "LIGHT WEIGHT TRUSS ROOF AND FLOOR" MARKINGS AS PER FLORIDA STATUTE 633.027, PLACED AS DIRECTED BY THE FIRE MARSHAL

EMERGENCY LIGHTING AND EXIT SIGNS, SHALL BE PROVIDED AS DIRECTED BY THE FIRE MARSHAL, AND SHALL BE WIRED PER NEC 100-12F.

NOTE

SMOKE DETECTORS SHALL BE MOUNTED NOT LESS THAN 90" ABOVE FINISHED FLOOR AND SHALL BE THE IONIZATION TYPE, INTERLOCKED TOGETHER, POWERED FROM EACH STORE PANEL W/BATTERY BACKUP

LEGEND



EXIT LIGHT - ARROW REPRESENTS DIRECTION OF EXIT - LG. = PRIMARY, SM. = SECONDARY

WALL HUNG "ABC" FIRE EXTINGUISHER

DOOR /CLOSER FOR EXITING OR RATING REASONS

PANIC DEVICE

-ROOM SQUARE FOOTAGE -ROOM OCCUPANCY LOAD

PRIMARY EGRESS W/EXIT CAPACITY

SECONDARY EGRESS

OLDO DUAL HEAD EMILIGHT W/ BAT. PAK

OCCUPANCY LOAD - ASSEMBLY

AREA	TOTAL S.F.	ALLOWABLE	OCCUPANTS
ASSEMBLY HALL:	3219	SEATING PLAN	228
NURSURY:	193	1/15	13
RESTROOMS:	294	1/50	6
SERVING AREA:	207	1/100	3
OFFICE (NON-CONCURRENT):	193	1/50	(4)
CONFERENCE: (NON-CONCURRENT):	212	1/15	(14)
LOBBY (NON-CONCURRENT):	594	1/5	(119)
BUILDING (WALLS & CLOSETS):	535	1/300	2
LOFT MEZZININE:	762	1/300	5 (MAX.)
BLDG. TOTAL	6209		257

REVISION

10 AUG 2012 17 AUG 2012

DRAWN:

DATE: 01 AUG 2012

COMM 2K1239

SHEET:

3 ∘ 3

