



06 APRIL 2021

BUILDER: S & S CONSTRUCTION

CLIENT: HALL RESIDENCE

ADDRESS: Cobblestone S/D (Columbia County)

BUILDING DEPARTMENT: COLUMBIA COUNTY BUILDING DEPARTMENT

TO WHOM IT MAY CONCERN,

PLEASE ACCEPT THIS LETTER AS APPROVAL OF THE INSTALLATION
OF THE 1/2" TITAN ANCHOR BOLTS AT 48" O.C.

ADD ADDITIONAL 1/2" TITAN BOLT WITH 2" SQUARE WASHER AT ALL
CORNERS, BOTH DIRECTIONS.

IF YOU HAVE ANY FURTHER QUESTIONS, PLEASE DO NOT HESITATE TO
CONTACT ME.

SINCERELY,

NICHOLAS PAUL GEISLER

Digitally signed by: N. P. GEISLER
DN: CN = N. P. GEISLER C = US
O = AR0007005 OU =
ARCHITECT
Date: 2021.04.07 13:02:40 -05'00'