



Affine Engineering and Surveying, Inc.

0

Date:3/17/2024

Robert and Beth Giannone

561.703.6296

Re: **Elevation Letter– Lot 2 Hawk's Landing (PB 9, PGS 165-167). North mobile home**

SUBJECT:

FINISH FLOOR HEIGHT VERIFICATION

To whom it may concern,

During a field survey conducted 3/15/2024 on Lot 2, Hawk's Landing Plat – Parcel 31-4S-17-08915-102, the finish floor of the existing structure was measured. According to the plat of Hawk's Landing the minimum floor elevation is 94.00 feet. Based on the field survey, it was found that the Finish Floor of the modular building is at elevation 102.26 feet. Elevations are referenced to BM #6 as shown on the plat having an elevation of 92.72 feet (NAVD88 datum).

Victor O. Marrero, PE, PSM

Florida PSM 6586



Victor O
Marrero

Digitally signed
by Victor O
Marrero
Date:
2024.03.17
17:03:57 -04'00'

0 0 0 0 0 0 0 0 0
0 0 0 0 0