



COLUMBIA COUNTY FIRE RESCUE

Life Safety Services

P.O. BOX 1529 Lake City, Florida 32056
Office (386) 754-7071 Fax (386) 754-7064

Fire Chief
David L. Boozer

20 June 2014

TO: Troy Crews
Columbia County Building and Zoning

FROM: David L. Boozer
Fire Chief

RE: Application # 1406-01
Bethlehem Methodist Church
Ft. White, Florida

A plans review was performed of the submitted plans for the Bethlehem Methodists Church Fellowship Hall to be located at 712 SW Bethlehem Avenue, Ft. White, Florida. This building falls under Chapter 12, of the Florida Fire Prevention Code, 2009 edition. I recommend approval with the following conditions:

- Addition of Emergency Lighting, Outside Rear Elevation
 - NFPA A.7.9.1.1 Emergency lighting outside the building should provide illumination to either a public way or a distance away from the building that is considered safe, whichever is closest to the building being evacuated.
 - NFPA 7.9.1.2 - For the purposes of 7.9.1.1, exit access shall include only designated stairs, aisles, corridors, ramps, escalators, and passageways leading to an exit. For the purposes of 7.9.1.1 exit discharges shall include only designated stairs, ramps, aisles, walkways and escalators leading to a public way.
- Mark building with Light Weight Truss Symbols according to the Florida Fire Marshals rule 69A-3.012 for Uniform Code building or 69A60.008 for Minimum Code

Should you require any additional information, please feel free to contact my office.

Sincerely,

David L. Boozer



COLUMBIA COUNTY FIRE RESCUE

Life Safety Services

P.O. BOX 1529 Lake City, Florida 32056
Office (386) 754-7071 Fax (386) 754-7064

Fire Chief
David L. Boozer

20 June 2014

TO: Troy Crews
Columbia County Building and Zoning

FROM: David L. Boozer
Fire Chief

RE: Application # 1406-01
Bethlehem Methodist Church
Ft. White, Florida

A plans review was performed of the submitted plans for the Bethlehem Methodists Church Fellowship Hall to be located at 712 SW Bethlehem Avenue, Ft. White, Florida. This building falls under Chapter 12, of the Florida Fire Prevention Code, 2009 edition. I recommend approval with the following conditions:

- Addition of Emergency Lighting, Outside Rear Elevation
 - NFPA A.7.9.1.1 Emergency lighting outside the building should provide illumination to either a public way or a distance away from the building that is considered safe, whichever is closest to the building being evacuated.
 - NFPA 7.9.1.2 - For the purposes of 7.9.1.1, exit access shall include only designated stairs, aisles, corridors, ramps, escalators, and passageways leading to an exit. For the purposes of 7.9.1.1 exit discharges shall include only designated stairs, ramps, aisles, walkways and escalators leading to a public way.
- Mark building with Light Weight Truss Symbols according to the Florida Fire Marshals rule 69A-3.012 for Uniform Code building or 69A60.008 for Minimum Code

Should you require any additional information, please feel free to contact my office.

Sincerely,

David L. Boozer

Permit Details

Permit Information

Permit #: 000032239 **Septic #:** 14-0384
Issued: Wednesday, August 27, 2014
Permit Type: FELLOWSHIP HALL
Subdivision:
Parcel #: 05-7S-17-09916-000
Owner: BETHLEHEM METHODIST CHURCH
Address: 712 SW BETHLEHEM AVE FT. WHITE FL 32038
Zoning: A-3
Flood Zone: X

Contractor Information

Contractor: MARK WILLIAMS
Address: POB 226 FT. WHITE FL 32038
License: CBC1257701

Notes:
 NOC ON FILE.
Inspection Notes:
 LINTEL 10 15 14-TC

[Inspection Log](#) [Documents](#)

	File Name	Size
	Permit-32239.pdf	736.25kB

[Close Window](#)