



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

07/24/2021

Permit # 000041976

L-27859

JT Builders

Re: Lot 29 Cannon Creek Place

To Whom It May Concern:

The top of the finished slab on said Lot 29 is 97.35 feet. The building permit requires the minimum floor to be 97 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,

L. Scott Britt
LS 5757