



Britt Surveying and Mapping, LLC

1438 SW Main Blvd • Lake City, FL 32025

386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

09/18/2024

L-30782

Re: 03752-421

Melanie Walstrom

To Whom It May Concern:

The finished floor elevation of the new residence is found to be 87.79 feet. The plat of record shows a minimum floor elevation of 85.5 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,


L. Scott Britt
LS 5757

