COMcheck Software Version COMcheckWeb

Interior Lighting Compliance Certificate

Project Information

Energy Code: 2020 Florida Building Code, Energy Conservation

Lake City TRC Build-In Project Title:

Alteration Project Type:

Construction Site: 215 SW Home Depot Dr Lake City, Florida 32025 Owner/Agent: The Home Depot 2455 Paces Ferry Rd. Atlanta, Georgia 30339-4024 (770) 433-8211

WD Partners 7007 Discovery Blvd. Dublin, Ohio 43017 (614) 634-7000

Designer/Contractor:

Allowed Interior Lighting Power

A Area Category	B Floor Area (ft2)	C Allowed Watts / ft2	D Allowed Watts
1-Tool Rental Center (Retail:Sales Area)	1958	1.22	2389
2-Tool Rental Center Maintenance Room (Common Space Types:Workshop)	209	1.14	238
		Total Allowed Watts =	2627

Proposed Interior Lighting Power

A Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	B Lamps/ Fixture	C # of Fixture	D Fixture Watt.	(C X D)
Tool Rental Center (Retail: Sales Area, 1958 sq.ft.) LED: A: 2'x4' LED: Other:	1	10	123	1230
Tool Rental Center Maintenance Room (Common Space Types: Workshop, LED: A1: 2'x4' LED: Other: LED: U: Other:	209 sq.ft.) 1 1	2 1	123 27	246 27
	To	tal Propose	ed Watts =	1503

Interior Lighting PASSES

Interior Lighting Compliance Statement

Compliance Statement: The proposed interior lighting alteration project represented in this document is consistent with the building plans, specifications, and other calculations submitted with this permit application. The proposed interior lighting systems have been designed to meet the 2020 Florida Building Code, Energy Conservation requirements in COMcheck Version COMcheckWeb and to comply with any applicable mandatory requirements listed in the Inspection Checklist.

Gregory B. Holman, PE

Name - Title

05/05/2023

Date

Project Title: Lake City TRC Build-In Report date: 05/01/23

Data filename: Page 1 of 6

COMcheck Software Version COMcheckWeb

Exterior Lighting Compliance Certificate

Project Information

Energy Code: 2020 Florida Building Code, Energy Conservation

Lake City TRC Build-In Project Title:

Project Type: Alteration

Exterior Lighting Zone 4 (High activity metropolitan commercial district (LZ4))

Construction Site: 215 SW Home Depot Dr Lake City, Florida 32025 Owner/Agent: The Home Depot 2455 Paces Ferry Rd. Atlanta, Georgia 30339-4024 (770) 433-8211

Designer/Contractor: **WD Partners** 7007 Discovery Blvd. Dublin, Ohio 43017 (614) 634-7000

Allowed Exterior Lighting Power

A Area/Surface Category	B Quantity	C Allowed Watts /	D Tradable Wattage	E Allowed Watts (B X C)
Tool Rental Center wall (Illuminated area of facade wall or surface)	1180 ft2	0.15	No	177
		Total Tradable	e Watts (a) =	0
		Total Allo	wed Watts =	177
	Total Allowe	d Supplementa	l Watts (b) =	900

- (a) Wattage tradeoffs are only allowed between tradable areas/surfaces.
- (b) A supplemental allowance equal to 900 watts may be applied toward compliance of both non-tradable and tradable areas/surfaces.

Proposed Exterior Lighting Power

Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	B Lamps/ Fixture		D Fixture Watt.	E (C X D)
Tool Rental Center wall (Illuminated area of facade wall or surface, 1180 ft	2): Non-trad	able Wat	tage	
LED: E2: LED Wallpack: Other:	1	2	45	90
LED: F: LED POST: Other:	1	1	76	76
	Total Tradah	le Pronose	d Watte -	0


Exterior Lighting PASSES

Exterior Lighting Compliance

Compliance Statement: The proposed exterior lighting alteration project represented in this document is consistent with the building plans, specifications, and other calculations submitted with this permit application. The proposed exterior lighting systems have been designed to meet the 2020 Florida Building Code, Energy Conservation requirements in COMcheck Version COMcheckWeb and to comply with any applicable mandatory requirements listed in the Inspection Checklist.

Gregory B. Holman, PE

Name - Title



05/05/2023

Date

Project Title: Lake City TRC Build-In Report date: 05/01/23

Data filename: Page 2 of 6

COMcheck Software Version COMcheckWeb Inspection Checklist Energy Code: 2020 Florida Building Code, Energy Conservation

Requirements: 100.0% were addressed directly in the COMcheck software

Text in the "Comments/Assumptions" column is provided by the user in the COMcheck Requirements screen. For each requirement, the user certifies that a code requirement will be met and how that is documented, or that an exception is being claimed. Where compliance is itemized in a separate table, a reference to that table is provided.

Section # & Req.ID	Plan Review	Complies?	Comments/Assumptions
C103.2 [PR4] ¹	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the interior lighting and electrical systems and equipment and document where exceptions to the standard are claimed. Information provided should include interior lighting power calculations, wattage of bulbs and ballasts, transformers and control devices.	□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.
C103.2 [PR8] ¹	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the exterior lighting and electrical systems and equipment and document where exceptions to the standard are claimed. Information provided should include exterior lighting power calculations, wattage of bulbs and ballasts, transformers and control devices.	□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.

Additional Comments/Assumptions:

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Project Title: Lake City TRC Build-In Report date: 05/01/23 Data filename: 3 of 6 Page

Section #	Rough-In Electrical Inspection	Complies?	Comments/Assumptions
& Req.ID		-	
C405.2.2. 2 [EL22] ¹		☐Complies ☐Does Not ☐Not Observable ☐Not Applicable	Requirement will be met.
C405.2.1, C405.2.1. 1 [EL18] ¹	Occupancy sensors installed in	□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.
C405.2.1. 2 [EL19] ¹	Occupancy sensors control function in warehouses: In warehouses, the lighting in aisleways and open areas is controlled with occupant sensors that automatically reduce lighting power by 50% or more when the areas are unoccupied. The occupant sensors control lighting in each aisleway independently and do not control lighting beyond the aisleway being controlled by the sensor.	□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.
C405.2.1. 3 [EL20] ¹		□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.
1,		□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Project Title: Lake City TRC Build-In

Data filename: Report date: 05/01/23

Page 4 of 6

Section			
# & Req.ID	Rough-In Electrical Inspection	Complies?	Comments/Assumptions
C405.2.3, C405.2.3. 1,	Daylight zones provided with individual controls that control the lights independent of general area lighting. See code section C405.2.3 Daylight-responsive controls for applicable spaces, C405.2.3.1 Daylight responsive control function and section C405.2.3.2 Sidelit zone.	□Complies □Does Not □Not Observable □Not Applicable	Exception: Requirement does not apply.
C405.2.4 [EL26] ¹	Separate lighting control devices for specific uses installed per approved lighting plans. 1. Display and accent lighting, lighting in display cases, supplemental task lighting and lighting equipment for sale shall have occupancy sensor control. 2) Sleeping units shall have auto off controls.	□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.
C405.2.5 [EL28] ³	Manual lighting controls are in a location with ready access and where controlled lights are visible.	□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.
C405.2.6 [EL30] ³	Exterior lighting systems provided with controls complying with C405.2.6.1 through C405.2.6.4 for daylight shutoff and decorative lighting shutoff.	□Complies □Does Not □Not Observable □Not Applicable	Exception: Lighting specific to covered vehicle egress where required for safety, security or eye adaptation.
C405.6 [EL26] ²	Low-voltage dry-type distribution electric transformers meet the minimum efficiency requirements of Table C405.6.	□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.
C405.7 [EL27] ²	Electric motors meet the minimum efficiency requirements of Tables C405.7(1) through C405.7(4). Efficiency verified through certification under an approved certification program or the equipment efficiency ratings shall be provided by motor manufacturer (where certification programs do not exist).	□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.
	Escalators and moving walks comply with ASME A17.1/CSA B44 and have automatic controls configured to reduce speed to the minimum permitted speed in accordance with ASME A17.1/CSA B44 or applicable local code when not conveying passengers.	□Complies □Does Not □Not Observable □Not Applicable	Exception: Requirement does not apply.
C405.5.3 [EL29] ²	Total voltage drop across the combination of feeders and branch circuits <= 5%.	□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.

Additional Comments/Assumptions:

1 High Impact (Tier 1)	2	Medium Impact (Tier 2)	3	Low Impact (Tier 3)

Project Title: Lake City TRC Build-In

Data filename: Report date: 05/01/23

Page 5 of 6

Section # & Req.ID	Final Inspection	Complies?	Comments/Assumptions
C408.2.5. Furnished O&M instructions for systems and equipment to the building owner or designated		□Complies □Does Not □Not Observable	Requirement will be met.
	representative.	□Not Observable □Not Applicable	
C405.3.2 [FI18] ¹	Interior installed lamp and fixture lighting power is consistent with what	□Complies □Does Not	See the Interior Lighting fixture schedule for values.
	is shown on the approved lighting plans, demonstrating proposed watts are less than or equal to allowed watts.		
C405.4.2 [FI19] ¹	Exterior lighting power is consistent with what is shown on the approved lighting plans, demonstrating proposed watts are less than or equal to allowed watts.	□Complies □Does Not	See the Exterior Lighting fixture schedule for values.
		□Not Observable □Not Applicable	
C408.1.1 [FI57] ¹	Building operations and maintenance documents will be provided to the owner. Documents will cover manufacturers' information, specifications, recommendations, programming procedures and means of illustrating to owner how building, equipment and systems are intended to be installed, maintained, and operated. Regular maintenance actions shall be clearly stated on accessible label.	□Complies □Does Not □Not Observable □Not Applicable	Requirement will be met.
C408.3 [FI33] ¹	Lighting systems have been tested to ensure proper calibration, adjustment, programming, and operation.	☐Complies ☐Does Not ☐Not Observable ☐Not Applicable	Requirement will be met.

Additional Comments/Assumptions:

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Project Title: Lake City TRC Build-In

Data filename: Report date: 05/01/23

Page 6 of 6