



STATE OF FLORIDA
DEPARTMENT OF HEALTH
ONSITE SEWAGE TREATMENT AND DISPOSAL
SYSTEM

PERMIT #: 12-SC-2646521
APPLICATION #: AP1941522
DATE PAID: 3-7-23
FEE PAID: 425.00
RECEIPT #: _____
DOCUMENT #: PR1906961

CONSTRUCTION PERMIT FOR: OSTDS New
APPLICANT: LACI**23-0185 LAW
PROPERTY ADDRESS: 244 SW KERNAN Gln Fort White, FL 32038
LOT: _____ BLOCK: _____ SUBDIVISION: _____
PROPERTY ID #: 03832-231 [SECTION, TOWNSHIP, RANGE, PARCEL NUMBER]
[OR TAX ID NUMBER]

SYSTEM MUST BE CONSTRUCTED IN ACCORDANCE WITH SPECIFICATIONS AND STANDARDS OF SECTION 381.0065, F.S., AND CHAPTER 64E-6, F.A.C. DEPARTMENT APPROVAL OF SYSTEM DOES NOT GUARANTEE SATISFACTORY PERFORMANCE FOR ANY SPECIFIC PERIOD OF TIME. ANY CHANGE IN MATERIAL FACTS, WHICH SERVED AS A BASIS FOR ISSUANCE OF THIS PERMIT, REQUIRE THE APPLICANT TO MODIFY THE PERMIT APPLICATION. SUCH MODIFICATIONS MAY RESULT IN THIS PERMIT BEING MADE NULL AND VOID. ISSUANCE OF THIS PERMIT DOES NOT EXEMPT THE APPLICANT FROM COMPLIANCE WITH OTHER FEDERAL, STATE, OR LOCAL PERMITTING REQUIRED FOR DEVELOPMENT OF THIS PROPERTY.

SYSTEM DESIGN AND SPECIFICATIONS

T [1,200] GALLONS / GPD _____ Septic Tank CAPACITY
A [] GALLONS / GPD _____ N/A CAPACITY
N [] GALLONS GREASE INTERCEPTOR CAPACITY [MAXIMUM CAPACITY SINGLE TANK:1250 GALLONS]
K [] GALLONS DOSING TANK CAPACITY [] GALLONS @ [] DOSES PER 24 HRS #Pumps []

D [575] SQUARE FEET _____ Drainfield SYSTEM
R [] SQUARE FEET _____ N/A SYSTEM

A TYPE SYSTEM: [] STANDARD [x] FILLED [] MOUND []

I CONFIGURATION: [x] TRENCH [] BED []

N

F LOCATION OF BENCHMARK: Nail in oak tree with pink ribbon east of site

I ELEVATION OF PROPOSED SYSTEM SITE [46.00] [INCHES / FT] [ABOVE / BELOW] BENCHMARK/REFERENCE POINT

E BOTTOM OF DRAINFIELD TO BE [55.00] [INCHES / FT] [ABOVE / BELOW] BENCHMARK/REFERENCE POINT

L

D FILL REQUIRED: [9.00] INCHES EXCAVATION REQUIRED: [0.00] INCHES

O The system is sized for 5 bedrooms with a maximum occupancy of 10 persons (2 per bedroom), for a total estimated flow of 460 gpd.

T

H

E

R

SPECIFICATIONS BY: Cassandra Bonds TITLE: Environmental Specialist I

APPROVED BY: Cassandra Bonds TITLE: Environmental Specialist I Columbia CHD

DATE ISSUED: 03/10/2023 EXPIRATION DATE: 09/10/2024

DH 4016, 08/09 (Obsoletes all previous editions which may not be used)

Incorporated: 64E-6.003, FAC

[Handwritten signature]



STATE OF FLORIDA
DEPARTMENT OF HEALTH
ONSITE SEWAGE TREATMENT AND DISPOSAL
SYSTEM
APPLICATION FOR CONSTRUCTION PERMIT

FW

SSO 046306370

PERMIT NO. 23-0185
DATE PAID: 3/2/23
FEE PAID: 425.00
RECEIPT #: 1941522

APPLICATION FOR:

☒ New System ☐ Existing System ☐ Holding Tank ☐ Innovative
☐ Repair ☐ Abandonment ☐ Temporary ☐ w perk test

APPLICANT: Laci Law

AGENT: Heide Morrison (heidemorrison@gmail.com)

TELEPHONE: 386-984-9334

MAILING ADDRESS: 313 NW Brook loop, Lake City, FL, 32055

TO BE COMPLETED BY APPLICANT OR APPLICANT'S AUTHORIZED AGENT. SYSTEMS MUST BE CONSTRUCTED BY A PERSON LICENSED PURSUANT TO 489.105(3)(m) OR 489.552, FLORIDA STATUTES. IT IS THE APPLICANT'S RESPONSIBILITY TO PROVIDE DOCUMENTATION OF THE DATE THE LOT WAS CREATED OR PLATTED (MM/DD/YY) IF REQUESTING CONSIDERATION OF STATUTORY GRANDFATHER PROVISIONS.

PROPERTY INFORMATION

LOT: 31 BLOCK: N/A SUBDIVISION: N/A PLATTED: N/A

PROPERTY ID #: 16-6S16-03832-231 ZONING: _____ I/M OR EQUIVALENT: ☐ Y ☐ N

PROPERTY SIZE: 5.01 ACRES WATER SUPPLY: ☒ PRIVATE PUBLIC ☐ ☐ ≤2000GPD ☐ >2000GPD

IS SEWER AVAILABLE AS PER 381.0065, FS? ☐ No ☒ Yes DISTANCE TO SEWER: 100 FT

PROPERTY ADDRESS: 244 SW Kernan Gln, Fort White

DIRECTIONS TO PROPERTY: Hwy 47 S to take a R on SW Elim Church Rd, go 0.5 miles take a R on SW Henderson Terr, go 0.8 miles and take

a R on SW Kernan Gln, Last property on the right corner

BUILDING INFORMATION

☒ RESIDENTIAL ☐ COMMERCIAL

Unit No	Type of Establishment	No. of Bedrooms	Building Area Sqft	Commercial/Institutional System Design Table 1, Chapter 64E-6, FAC
1	New DW Mobile home	5 bedroom	2136 Sq Ft	
2				
3				
4				

☒ Floor/Equipment Drains ☐ Other (Specify) _____

SIGNATURE: Heide Morrison

DATE: 02/20/23

23-0185

