



CONCRETE / MASONRY / METALS GENERAL NOTES:

DESIGN SOIL BEARING PRESSURE: 1500 PSF.

EXPANSIVE SOILS: WHERE DIRECTED BY THE SOILS ENGINEER, SOIL AUGMENTATION PER THE SOILS ENGINEER'S SPECIFICATIONS SHALL BE IMPLEMENTED PRIOR TO PLACING ANY FOUNDATIONS - TESTS AS SPECIFIED SHALL BE PERFORMED TO DETERMINE THE SUITABILITY OF THE SUB-GRADE TO SUPPORT THE DESIGN LOADS.

CLEAN SAND FILL OVER STRIPPED AND COMPAKTED EXISTING GD. SHALL BE PLACED IN 12" LIFTS, BOTH SUB-SOIL AND FILL COMPAKATION SHALL BE NOT LESS THAN 98% AS MEASURED BY A MODIFIED PROCTOR TEST AT THE RATE OF ONE TEST FOR EACH 1500 SF OF BUILDING PAD AREA, OR FRACTION THEREOF, FOR EACH 12" LIFT.

REINFORCING STEEL SHALL BE GRADE 60 AND MEET THE REQUIREMENTS OF ASTM A615, ALL BENDS SHALL BE MADE COLD.

WELDED WIRE MESH SLAB REINFORCING SHALL MEET THE REQUIREMENTS OF ASTM A185 - MIN. YEILD STRESS = 85 KSI.

CONCRETE SHALL BE STANDARD MIX F'c = 3000 PSI FOR ALL FTGS, SLABS, COLUMNS AND BEAMS OR SHALL BE STANDARD PUMP MIX F'c = 3000 PSI. STRENGTH SHALL BE ATTAINED WITHIN 28 DAYS OF PLACEMENT. MIXING, PLACING AND FINISHING SHALL BE AS PER ACI STANDARDS.

CONCRETE BLOCK SHALL BE AS PER MANUFACTURER'S PRODUCT GUIDE FOR ASTM C-90 REQUIREMENTS WITH MEDIUM SURFACE FINISH - F'm = 1500 PSI.

MORTAR SHALL BE TYPE "M" OR "N" FOR ALL MASONRY UNITS.

STRUCTURAL STEEL SHALL CONFORM TO ASTM A36 STANDARDS FOR STRENGTH, BOLTS SHALL BE ASTM A307 / GRADE 1 OR A325, AS PER PLAN REQUIREMENTS.

WELDS SHALL BE AS PER "AMERICAN WELDING SOCIETY" STANDARDS FOR STRUCTURAL STEEL APPLICATIONS.

2x4 P/T WOOD GILL, CONT., ALL AROUND, W/ 5/8"~ A.B. W/ 3" SQ. X 1/4" PLATE WASHERS WITHIN 12-16" FROM EACH CORNER, EA. WAY, & WITHIN 8-12" FROM ALL WALL OPENINGS / ENDS - 1/2"~ A.B. W/ 2" SQ. WASHERS ALONG EACH RUN @ 48" O.C., MAX. - ALL ANCHOR BOLTS SHALL HAVE A MINIMUM OF 8" EMBEDMENT INTO THE CONCRETE.

K. 3000 PSI CONCRETE SLAB
TERMESH CONCRETE ADDITIVE,
TREATED, CLEAN COMPACTED FILL

SECTION A-A

Scale: 3/4" = 1'-0"

Diagram illustrating a concrete foundation and wall assembly. The foundation is a 2500 PSI concrete footing with a 20" width, 7" thickness, and 6" height. It contains 2-*5 bars continuous on wire or plastic chairs. The wall is an 8" CMU bond beam with #5 bars, continuous with 25" lap. It is supported by a 18" x 18" x 18" concrete ell at 48" o.c. max. Dowels are used at 48" o.c. max. The concrete is labeled CMU.

CMU

Σ

2500 PSI CONC. FOOTING

20"

7"

6"

7"

8" CMU BOND BEAM W/ #5 BAR CONT/25" MIN. LAP

#5 DOWELS @ 48" O.C. MAX.

#5 ELLS X 18" X 18" @ 48" O.C. MAX.

18"

6"

7"

7"

20"

SECTION

SCALE: 3/4" = 1'-0"

OPTIONAL MONO SECTION

CALE: not to scale

4" THK. 3000 PSI CONCRETE SLAB
W/ FIBERMESH CONCRETE ADDITIVE,
OVER TREATED, CLEAN, COMPACTED FILL

OVER TREATED, CLEAN COMPACTED FILL

A technical diagram of a concrete wall section. A vertical rebar cage is shown on the left, consisting of a top horizontal bar and several vertical bars. A dashed vertical line extends from the top of the cage through the wall. A dimension line with arrows at both ends spans the distance from the vertical line to the right edge of the wall. The dimension is labeled "18"".

" CMH 6" 7 points to wall or min.

Diagram of a rectangular concrete footing. The width is labeled as 3' and the thickness is labeled as 12". The material is specified as 2500 PSI CONC. FOOTING.

Figure 1. A schematic diagram of the experimental setup. The inset shows the optical arrangement of the laser beam and the sample.

PORCH / CARPORT STEMWALL DETAIL

SCALE: 3/4" = 1'-0" S.1

CUSTOM HOME FOR:
HUMPHREY RESIDENCE
COLUMBIA COUNTY, FLORIDA

SHEET NUMBER
S.1