

# Inspection Checklist for Permit #000054843

Notes:

<b>Order</b>	<b>Category</b>	<b>Inspection</b>	<b>Requirements</b>
1	Swimming Pool	<b>Pool Steel and Ground</b> <i>Reviews steel reinforcing and equipotential bonding grid. Ref: NEC 680.26, FBC 454.1.10.4.2</i>	
2	Engineering	<b>Setbacks</b> <i>Confirms buildings, structures, and improvements are within required property setbacks. Columbia County LDR 4.1</i>	
3	Swimming Pool	<b>Pool Footer</b> <i>Inspects reinforcing and bonding in pool footers. Ref: FBC 454.1.6</i>	
4	Swimming Pool	<b>Pool Deck/Piping Pressure</b> <i>Verifies deck drains and pool piping under pressure. Ref: FBC 454.1.6.5.1</i>	
5	Electrical	<b>Pool/Deck Bonding</b> <i>Ensures all metallic pool parts and decking are bonded together. Ref: NEC Art. 680.26</i>	
6	City of Lake City Utilities	<b>Lake City Utilities Tap Inspection</b> <i>Conducted when required by the City to verify proper connection and availability of utility services. Ref: City of Lake City</i>	
7	Swimming Pool	<b>Pool Safety and Final</b> <i>Ensures barriers, alarms, and final system safety. Ref: FBC 454.1.3.1.9</i>	