

DATE 06/15/2009

Columbia County Building Permit

PERMIT

This Permit Must Be Prominently Posted on Premises During Construction

000027879

APPLICANT GLEN WILLIAMS PHONE 386.697.5037
ADDRESS 619 SE COUNTRY CLUB ROAD LAKE CITY FL 32025
OWNER SYLVESTER NASH PHONE 386.623.8244
ADDRESS 257 NE JOY GLN LAKE CITY FL 32025
CONTRACTOR GLEN WILLIAMS PHONE 386.623.1912
LOCATION OF PROPERTY 41-N TO TAMMY LN TO COLVIN,TL GO 1/4 MILE TO JOY GLN,TR
PROPERTY @ END ON L.

TYPE DEVELOPMENT M/H/UTILITY ESTIMATED COST OF CONSTRUCTION 0.00
HEATED FLOOR AREA TOTAL AREA HEIGHT STORIES
FOUNDATION WALLS ROOF PITCH FLOOR
LAND USE & ZONING RSF-MH-2 MAX. HEIGHT 35
Minimum Set Back Requirments: STREET-FRONT 25.00 REAR 15.00 SIDE 10.00
NO. EX.D.U. 1 FLOOD ZONE X DEVELOPMENT PERMIT NO.

PARCEL ID 17-3S-17-04967-070 SUBDIVISION 5 POINTS ACRES
LOT 10 BLOCK PHASE UNIT 2 TOTAL ACRES 1.00

IH0000972
Culvert Permit No. Culvert Waiver Contractor's License Number Applicant/Owner/Contractor
EXISTING 09-0296-E CFS HD N
Driveway Connection Septic Tank Number LU & Zoning checked by Approved for Issuance New Resident

COMMENTS: 1 FOOT ABOVE RD. EXISTING M/H TO BE REMOVED. PLS VERIFY SETBACKS -
EXISTING M/H APPEARED TO ENCROACH ON WEST SIDE.

Check # or Cash CASH REC'D.

FOR BUILDING & ZONING DEPARTMENT ONLY

(footer/Slab)

Temporary Power date/app. by Foundation date/app. by Monolithic date/app. by
Under slab rough-in plumbing date/app. by Slab date/app. by Sheathing/Nailing date/app. by
Framing date/app. by Insulation date/app. by
Rough-in plumbing above slab and below wood floor date/app. by Electrical rough-in date/app. by
Heat & Air Duct date/app. by Peri. beam (Lintel) date/app. by Pool date/app. by
Permanent power date/app. by C.O. Final date/app. by Culvert date/app. by
Pump pole date/app. by Utility Pole date/app. by M/H tie downs, blocking, electricity and plumbing date/app. by
Reconnection date/app. by RV date/app. by Re-roof date/app. by

BUILDING PERMIT FEE \$ 0.00 CERTIFICATION FEE \$ 0.00 SURCHARGE FEE \$ 0.00
MISC. FEES \$ 250.00 ZONING CERT. FEE \$ 50.00 FIRE FEE \$ 0.00 WASTE FEE \$
FLOOD DEVELOPMENT FEE \$ FLOOD ZONE FEE \$ 25.00 CULVERT FEE \$ TOTAL FEE 325.00
INSPECTORS OFFICE CLERKS OFFICE

NOTICE: IN ADDITION TO THE REQUIREMENTS OF THIS PERMIT, THERE MAY BE ADDITIONAL RESTRICTIONS APPLICABLE TO THIS PROPERTY THAT MAY BE FOUND IN THE PUBLIC RECORDS OF THIS COUNTY. AND THERE MAY BE ADDITIONAL PERMITS REQUIRED FROM OTHER GOVERNMENTAL ENTITIES SUCH AS WATER MANAGEMENT DISTRICTS, STATE AGENCIES, OR FEDERAL AGENCIES.

"WARNING TO OWNER: YOUR FAILURE TO RECORD A NOTICE OF COMMENCEMENT MAY RESULT IN YOUR PAYING TWICE FOR IMPROVEMENTS TO YOUR PROPERTY. IF YOU INTEND TO OBTAIN FINANCING, CONSULT WITH YOUR LENDER OR AN ATTORNEY BEFORE RECORDING YOUR NOTICE OF COMMENCEMENT."

EVERY PERMIT ISSUED SHALL BECOME INVALID UNLESS THE WORK AUTHORIZED BY SUCH PERMIT IS COMMENCED WITHIN 180 DAYS AFTER ITS ISSUANCE, OR IF THE WORK AUTHORIZED BY SUCH PERMIT IS SUSPENDED OR ABANDONED FOR A PERIOD OF 180 DAYS AFTER THE TIME THE WORK IS COMMENCED. A VALID PERMIT RECIEVES AN APPROVED INSPECTION EVERY 180 DAYS. WORK SHALL BE CONSIDERED NOT SUSPENDED, ABANDONED OR INVALID WHEN THE PERMIT HAS RECIEVED AN APPROVED INSPECTION WITHIN 180 DAYS OT THE PREVIOUS INSPECTION.

The Issuance of this Permit Does Not Waive Compliance by Permittee with Deed Restrictions.

PERMIT APPLICATION / MANUFACTURED HOME INSTALLATION APPLICATION

For Office Use Only (Revised 1-10-08) Zoning Official 5/19/09 Building Official ND 5-19-0

AP# 0905-26 Date Received 5/18 By JW Permit # 27879

Flood Zone X Development Permit — Zoning RSF/MH-2 Land Use Plan Map Category RLD

Comments Existing MH to be removed.
Pls. verify setbacks - Existing MH appeared to encroach on West side

FEMA Map# _____ Elevation _____ Finished Floor _____ River _____ In Floodway _____

☒ Site Plan with Setbacks Shown ☒ EH # _____ ☒ EH Release ☒ Well letter ☐ Existing well

☒ Recorded Deed or Affidavit from land owner NA Letter of Auth. from installer ☐ State Road Access

☐ Parent Parcel # _____ ☐ STUP-MH _____ ☐ F W Comp. letter

IMPACT FEES: EMS _____ Fire _____ Corr _____ Road/Code _____

School _____ = TOTAL 0 ☒ out of County ☒ PRE-MAN approved w/ordinance

Property ID # 17-35-17-04967070 Subdivision Five Points Acres Lot-10 Unit 11

- New Mobile Home _____ Used Mobile Home ☒ MH Size 16x80 Year 1999
- Applicant Glen Williams Phone # 687-5037
- Address 619 SE Carly Circle Rd Lake City FL 32025
- Name of Property Owner Sylvester Bucky Nash Phone # 386-623-2244
- 911 Address 257 NE JOY GLEN LAKE CITY, FL 32025
- Circle the correct power company - FL Power & Light - Clay Electric
 (Circle One) - Suwannee Valley Electric - Progress Energy
- Name of Owner of Mobile Home Sylvester "Bucky" Nash Phone # 386-623-2244
- Address 3624 N.W. Brown Rd Lake City FL 32055
- Relationship to Property Owner Owner
- Current Number of Dwellings on Property 1
- Lot Size 1 acre Total Acreage 1 AC
- Do you : Have Existing Drive or Private Drive or need Culvert Permit or Culvert Waiver (Circle one)
 (Currently using) (Blue Road Sign) (Putting in a Culvert) (Not existing but do not need a Culvert)
- Is this Mobile Home Replacing an Existing Mobile Home yes (Spd)
- Driving Directions to the Property Take 41 Rd to Tammy Ln
6 1/4 mile to Colvin Ave turn Lt. Go 1/4 mile to Joy Elm
Turn Rt Property at end of Road, on Lt.
- Name of Licensed Dealer/Installer Glen Williams Phone # 623-1912
- Installers Address 619 SE Carly Circle Rd Lake City FL 32025
- License Number FL 0000972 Installation Decal # 303615

JW left message 5.19.09 \$325.00

PERMIT WORKSHEET


page 1 of 2

Installer Glenn Williams License # 2H0000472
 Manufacturer Fleetwood Length x Width 16 x 80
 Name of Owner of this Mobile Home Bucky Nash
 Phone 625-6244
 Address 3624 N.W. Brown Rd

NOTE: if home is a single wide fill out one half of the blocking plan
 if home is a triple or quad wide sketch in remainder of home

I understand Lateral Arm Systems cannot be used on any home (new or used)
 where the sidewall ties exceed 5 ft 4 in.

Installer's initials SW



New Home ☐ Used Home ☒ Year 1996
 Home installed to the Manufacturer's Installation Manual ☒
 Home is installed in accordance with Rule 15-C ☐
 Single wide ☒ Wind Zone II ☒ Wind Zone III ☐
 Double wide ☐ Installation Decal # 303615
 Triple/Quad ☐ Serial # GAF17754275154E21

PIER SPACING TABLE FOR USED HOMES

Load bearing capacity	Footer size (sq in)	16" x 16" (256)	18 1/2" x 18 1/2" (342)	20" x 20" (400)	22" x 22" (484)*	24" x 24" (576)*	26" x 26" (676)
1000 dsf	3'	4'	5'	6'	7'	8'	8'
1500 dsf	4'6"	6'	7'	8'	8'	8'	8'
2000 dsf	6'	8'	8'	8'	8'	8'	8'
2500 dsf	7'6"	8'	8'	8'	8'	8'	8'
3000 dsf	8'	8'	8'	8'	8'	8'	8'
3500 dsf	8'	8'	8'	8'	8'	8'	8'

* interpolated from Rule 15C-1 pier spacing table.

PIER PAD SIZES

I-beam pier pad size 18 x 18

Perimeter pier pad size 18 x 18

Other pier pad sizes (required by the mfg.)

Draw the approximate locations of marriage wall openings 4 foot or greater. Use this symbol to show the piers.

List all marriage wall openings greater than 4 foot and their pier pad sizes below.

Opening

Pier pad size

TIEDOWN COMPONENTS

Longitudinal Stabilizing Device (LSD)
 Manufacturer Oliver Inc
 Longitudinal Stabilizing Device w/ Lateral Arms
 Manufacturer

POPULAR PAD SIZES

Pad Size	Sq In
16 x 16	256
16 x 18	288
18.5 x 18.5	342
16 x 22.5	360
17 x 22	374
13 1/4 x 26 1/4	348
20 x 20	400
17 3/16 x 25 3/16	441
17 1/2 x 25 1/2	446
24 x 24	576
26 x 26	676

ANCHORS

4 ft

5 ft

FRAME TIES

within 2' of end of home spaced at 5' 4" oc

OTHER TIES

Sidewall Longitudinal Marriage wall Shearwall
 Number 12

POCKET PENETROMETER TEST

The pocket penetrometer tests are rounded down to _____ psf or check here to declare 1000 lb. soil without testing.

x 1500 x 1500 x 1500

POCKET PENETROMETER TESTING METHOD

1. Test the perimeter of the home at 6 locations.
2. Take the reading at the depth of the footer.
3. Using 500 lb. increments, take the lowest reading and round down to that increment.

x 1500 x 1500 x 1500

TORQUE PROBE TEST

The results of the torque probe test is 290 inch pounds or check here if you are declaring 5' anchors without testing. A test showing 275 inch pounds or less will require 4 foot anchors.

Note: A state approved lateral arm system is being used and 4 ft. anchors are allowed at the sidewall locations. 1 under stand 5 ft anchors are required at all centerline tie points where the torque test reading is 275 or less and where the mobile home manufacturer may requires anchors with 4000 lb. holding capacity.

BLJ Installer's initials

ALL TESTS MUST BE PERFORMED BY A LICENSED INSTALLER

Installer Name

Allen Williams

Date Tested

8-14-09

Electrical

Connect electrical conductors between multi-wide units, but not to the main power source. This includes the bonding wire between multi-wide units. Pg.

Plumbing

Connect all sewer drains to an existing sewer tap or septic tank. Pg.

Connect all potable water supply piping to an existing water meter, water tap, or other independent water supply systems. Pg.

Site Preparation

Debris and organic material removed Yes
Water drainage Natural Swale Pad Other

Fastening multi wide units

Floor: Type Fastener: Length: Spacing:
Walls: Type Fastener: Length: Spacing:
Roof: Type Fastener: Length: Spacing:
For used homes a min. 30 gauge, 8" wide galvanized metal strip will be centered over the peak of the roof and fastened with galv. roofing nails at 2" on center on both sides of the centerline.

Gasket (weatherproofing requirement)

I understand a properly installed gasket is a requirement of all new and used homes and that condensation, mold, mildew and buckled marriage walls are a result of a poorly installed or no gasket being installed. I understand a strip of tape will not serve as a gasket.

Installer's initials

Type gasket

Installed:

Pg. Between Floors Yes
Between Walls Yes
Bottom of ridgebeam Yes

Weatherproofing

The bottomboard will be repaired and/or taped. Yes ✓ Pg.
Siding on units is installed to manufacturer's specifications. Yes
Fireplace chimney installed so as not to allow intrusion of rain water. Yes

Miscellaneous


Skirting to be installed. Yes No
Dryer vent installed outside of skirting. Yes N/A
Range downflow vent installed outside of skirting. Yes N/A
Drain lines supported at 4 foot intervals. Yes
Electrical crossovers protected. Yes
Other:

Installer verifies all information given with this permit worksheet is accurate and true based on the

Installer Signature Allen Williams

Date 8/14/09

S = 1500



S = 1500

S = 1500 = Piers shall be

Placed on 4'5"

S = 290 = 4' Anchors =

5'6"

Door Piers + Fireplace

Piers will Be Placed

where Required

S = 1500

S = 1500

Anchor

Main Beam Piers

Oliver Tec

Torque Test Site

1101 V

Oliver Tec

Columbia County Property Appraiser

DB Last Updated: 4/27/2009

2009 Preliminary Value

Tax Record

Property Card

Interactive GIS Map

Parcel: 17-3S-17-04967-070

Print

Search Result: 1
of 1

Owner & Property Info

Owner's Name	NASH SYLVESTER		
Site Address	JOY		
Mailing Address	3624 NW BROWN RD LAKE CITY, FL 32055		
Use Desc. (code)	MOBILE HOM (000200)		
Neighborhood	017317.01	Tax District	2
UD Codes	MKTA06	Market Area	06
Total Land Area	1.000 ACRES		
Description	LOT 10 FIVE POINTS ACRES S/D UNIT 2. ORB 532-398, 719-228, 739-847, 774-044, 788-2397 PROB#04-274 CP CATHERINE NASH 1033-671 THRU 703, WD 1034- 284 THRU 296.		


GIS Aerial



Property & Assessment Values

Mkt Land Value	cnt: (4)	\$11,726.00
Ag Land Value	cnt: (0)	\$0.00
Building Value	cnt: (1)	\$6,263.00
XFOB Value	cnt: (0)	\$0.00

Just Value	\$17,989.00
Class Value	\$0.00
Assessed Value	\$17,989.00
Exemptions	\$0.00
	County \$17,989.00



Columbia County Property Appraiser

J. Doyle Crews, CFA - Lake City, Florida - 386-758-1083

PARCEL: 17-3S-17-04967-070 - MOBILE HOM (000200)

Name:	NASH SYLVESTER	LandVal	\$11,726.00
Site:	JOY	BldgVal	\$6,263.00
	3624 NW BROWN	ApprVal	\$17,989.00
	RD	JustVal	\$17,989.00
Mail:	LAKE CITY, FL	Assd	\$17,989.00
	32055	Exmpt	\$0.00
Sales		County:	\$17,989.00 City:
Info		Taxable	\$17,989.00
		Other:	\$17,989.00
		School:	\$17,989.00

0 220 440 660 ft



>> Print as PDF <<

 LOT 10 FIVE POINTS ACRES S/D NASH SYLVESTER 17-3S
 UNIT 2. ORB 532-398, 719-228, 3624 NW BROWN RD
 739-847, 774-044, 788-2397 LAKE CITY, FL 32055
 PROB#04-274 CP CATHERINE NASH


BUSE 000800 MOBILE HME	AE? N	672 HTD AREA	91.710 INDE
MOD 2 MOBILE HME BATH	2.00	744 EFF AREA	24.762 E-RA
EXW 26 ALM SIDING FIXT		18423 RCN	
% N/A BDRM	1	34.00 %GOOD	6,263 B BLDG
RSTR 03 GABLE/HIP RMS			
RCVR 01 MINIMUM UNTS		³ FIELD CK:	
% N/A C-W%		³ LOC: 257 JOY GLN NE LAKE CITY	
INTW 04 PLYWOOD HGHT		³	
% N/A PMTR		³ +-----56-----	
FLOR 14 CARPET STYS	1.0	³ IBAS1993	
10% 08 SHT VINYL ECON		³ 1	
HTTP 04 AIR DUCTED FUNC		³ 2	
A/C 02 WINDOW SPCD		³ +-----32-----+---12---+	
QUAL 03 03 DEPR 09		³	IUSP1993I
FNDN N/A UD-1 N/A		³	1 1
SIZE N/A UD-2 N/A		³	2 2
CEIL N/A UD-3 N/A		³	I I
ARCH N/A UD-4 N/A		³	+---12---+
FRME 01 NONE UD-5 N/A		³	
KTCH 01 01 UD-6 N/A		³	
WDO N/A UD-7 N/A		³	
CLAS N/A UD-8 N/A		³	
OCC N/A UD-9 N/A		³	
COND 03 03 % N/A		³	
SUB A-AREA % E-AREA SUB VALUE		³	
BAS93 672 100 672 5657		³	
USP93 144 50 72 606		³	

 TOTAL 816 744 6263 -----
 -----EXTRA FEATURES----- FIELD CK:
 AE BN CODE DESC LEN WID HGHT QTY QL YR ADJ UNI


LAND AE CODE	DESC	ZONE TOPO	ROAD UTIL	{UD1 {UD2	{UD3 {UD4	FRONT BACK	DEPTH DT	FIELD CK: ADJUSTMENTS
Y 000200	MBL HM	A-1	0002					1.00 1.00 1.00
			0002 0003					
Y 009945	WELL/SEPT	A-1	0002					1.00 1.00 1.00 1
			0002 0003					
N 000000	VAC RES	A-1	0002					1.00 1.00 1.00
			0002 0003					
N 009947	SEPTIC	A-1	0002					1.00 1.00 1.00 1
			0002 0003					

1. A PLAT, PLAN, OR DRAWING SHOWING THE PROPERTY LINES OF THE PARCEL.
2. LOCATION OF PLANNED RESIDENT OR BUSINESS STRUCTURE ON THE PROPERTY WITH DISTANCES FROM AT LEAST TWO OF THE PROPERTY LINES TO THE STRUCTURE (SEE SAMPLE BELOW).
3. LOCATION OF THE ACCESS POINT (DRIVEWAY, ETC.) ON THE ROADWAY FROM WHICH LOCATION IS TO BE ADDRESSED WITH A DISTANCE FROM A PARALLEL PROPERTY LINE AND OR PROPERTY CORNER (SEE SAMPLE BELOW).
4. TRAVEL OF THE DRIVEWAY FROM THE ACCESS POINT TO THE STRUCTURE (SEE SAMPLE BELOW).

SAMPLE:



SITE PLAN BOX:



Identification Number GAFL75A27515WE21	Year 1996	Make WEST	Body XS	WT-L-BHP 76'	Vessel Regis. No.	Title Number 71822637
--	---------------------	---------------------	-------------------	------------------------	-------------------	---------------------------------

Registered Owner:

Date of Issue 05/01/2009

GREEN TREE FINANCIAL SERVICES CORP
PO DRAWER 4189
TALLA, FL 32315

Lien Release
 Interest in the described vehicle is hereby released
 By _____
 Title _____
 Date _____

IMPORTANT INFORMATION

- When ownership of the vehicle described herein is transferred, the seller **MUST** complete in full the Transfer of Title by Seller section at the bottom of the certificate of title.
- Upon sale of this vehicle, the seller must complete the notice of sale on the reverse side of this form.
- Remove your license plate from the vehicle.
- See the web address below for more information and the appropriate forms required for the purchaser to title and register the vehicle, mobile home or vessel: <http://www.hsmv.state.fl.us/html/titlinf.html>

Mail To:

GREEN TREE FINANCIAL SERVICES CORP
PO DRAWER 4189
TALLA, FL 32315

75330014 - Hernandez

CERTIFICATE OF TITLE

Identification Number GAFL75A27515WE21	Year 1996	Make WEST	Body XS	WT-L-BHP 76'	Vessel Regis. No.	Title Number 71822637
--	---------------------	---------------------	-------------------	------------------------	-------------------	---------------------------------

Lien Release
Interest in the described vehicle is hereby released

Prev State FL	Color ORANGE	Primary Brand	Secondary Brand	No of Brands	Use PRIVATE	Prev Issue Date 09/27/1996
-------------------------	------------------------	---------------	-----------------	--------------	-----------------------	--------------------------------------

Odometer Status or Vessel Manufacturer's Use	Hull Material	Prop	Date of Issue 05/01/2009
--	---------------	------	------------------------------------

Registered Owner

GREEN TREE FINANCIAL SERVICES CORP
PO DRAWER 4189
TALLA, FL 32315

1st Lienholder

NONE

DIVISION OF MOTOR VEHICLES

TALLAHASSEE

FLORIDA

DEPARTMENT OF HIGHWAY SAFETY AND MOTOR VEHICLES

Carl A. Ford
 Carl A. Ford
 Director

Electra Theodorides-Bustle
 Electra Theodorides-Bustle
 Executive Director

Control Number 91249050

TRANSFER OF TITLE BY SELLER (This section must be completed at the time of sale.)

Federal and/or state law require that the seller state the mileage, purchaser's name, selling price and date sold in connection with the transfer of ownership.
 Failure to complete or providing a false statement may result in fines and/or imprisonment.

This title is warranted to be free from any liens except as noted on the back of this certificate and the motor vehicle or vessel described is hereby transferred to:

Seller Must Enter Purchaser's Name:

Seller Must Enter Selling Price:

I/We state that this ☐ 3 or ☐ 6 digit odometer now reads _____ (no tenths) miles, date read _____ and I hereby certify that to the best of my knowledge the odometer reading:
☐ 1. reflects ACTUAL MILEAGE. ☐ 2. is IN EXCESS OF ITS MECHANICAL LIMITS. ☐ 3. is NOT THE ACTUAL MILEAGE.

UNDER PENALTIES OF PERJURY, I DECLARE THAT I HAVE READ THE FOREGOING DOCUMENT AND THAT THE FACTS STATED IN IT ARE TRUE.

SELLER Must
 Sign Here:

CO-SELLER Must
 Sign Here:

Print Here:

Print Here:

Selling Dealer's License Number:

Tax No.:

Tax Collected:

Auction Name:

License Number:

PURCHASER Must
 Sign Here:

CO-PURCHASER Must
 Sign Here:

Print Here:

Print Here:

NOTICE: \$19.00 PENALTY IS REQUIRED BY LAW IF NOT SUBMITTED FOR TRANSFER WITHIN 30 DAYS AFTER DATE OF PURCHASE

STATE OF FLORIDA

TOTAL P.02

LIEN SATISFACTION

VOID IF ALTERED

STATE OF FLORIDA

VOID IF ALTERED



STATE OF FLORIDA
DEPARTMENT OF HEALTH


APPLICATION FOR ONSITE SEWAGE DISPOSAL SYSTEM CONSTRUCTION PERMIT

Permit Application Number

09-02966

PART II - SITE PLAN

Scale: Each block represents 5 feet and 1 inch = 50 feet.



Notes:

Site Plan submitted by: Glen Williams Signature
Plan Approved ☒ Not Approved ☐
By: Salhi Ford EH Director Columbia County Health Department
Date: 0509 Title: agast

ALL CHANGES MUST BE APPROVED BY THE COUNTY HEALTH DEPARTMENT

Filed 5.18.09

CODE ENFORCEMENT DEPARTMENT
COLUMBIA COUNTY, FLORIDA
OUT OF COUNTY MOBILE HOME INSPECTION REPORT

COUNTY THE MOBILE HOME IS BEING MOVED FROM SWANNEE
OWNERS NAME Sylvester Nash PHONE _____ CELL 623-8244
INSTALLER Glen Williams PHONE 623-1812 CELL _____
INSTALLERS ADDRESS 619 SE Country Club Rd. Lake City FL
32055

MOBILE HOME INFORMATION

MAKE Fleetwood YEAR 1996 SIZE 16x X 80
COLOR Tan SERIAL No. GAFLT5A27515-WE21
WIND ZONE II SMOKE DETECTOR ✓

INTERIOR:

FLOORS Good
DOORS _____
WALLS _____
CABINETS _____
ELECTRICAL (FIXTURES/OUTLETS) Good

EXTERIOR:

WALLS / SIDING _____
WINDOWS _____
DOORS _____

STATUS:

APPROVED Good NOT APPROVED _____

NOTES: _____

INSTALLER OR INSPECTORS PRINTED NAME Glen Williams

Installer/Inspector Signature Glen Williams License No. THAW972 Date 5-18-09

ONLY THE ACTUAL LICENSE HOLDER OR A BUILDING INSPECTOR CAN SIGN THIS FORM.

NO WIND ZONE ONE MOBILE HOMES WILL BE PERMITTED. MOBILE HOMES PRIOR TO 1977 ARE PRE-HUD AND THE WIND ZONE MUST BE PROVEN TO BE PERMITTED.

BEFORE THE MOBILE HOME CAN BE MOVED INTO COLUMBIA COUNTY THIS FORM MUST BE COMPLETED AND RETURNED TO THE COLUMBIA COUNTY BUILDING DEPARTMENT.

ONCE MOVED INTO COLUMBIA COUNTY AN INSPECTOR MUST COMPLETE A PRELIMINARY INSPECTION ON THE MOBILE HOME. CALL 386-719-2038 TO SET UP THIS INSPECTION. NO PERMIT WILL BE ISSUED BEFORE THIS IS DONE.

Approved Glen Pavael
Code Enforcement Approval Signature Approved by Glen Williams Date _____

Out of Co.

CODE ENFORCEMENT
PRELIMINARY MOBILE HOME INSPECTION REPORT

DATE RECEIVED 6-11-09 BY LH IS THE M/H ON THE PROPERTY WHERE THE PERMIT WILL BE ISSUED? Y

OWNERS NAME Sylvester Nash PHONE _____ CELL 623-8244

ADDRESS _____

MOBILE HOME PARK _____ SUBDIVISION _____

DRIVING DIRECTIONS TO MOBILE HOME 441, (R) Tammy, (R) Calvin
1/2 mile (B) Joy at end on (L)

MOBILE HOME INSTALLER Glen Williams PHONE _____ CELL _____

MOBILE HOME INFORMATION

MAKE Fleetwood YEAR 96 SIZE 16 x 80 COLOR Tan

SERIAL No. AAFLT75A27515-WE21

WIND ZONE II Must be wind zone II or higher NO WIND ZONE I ALLOWED

INSPECTION STANDARDS

INTERIOR:

(P or F) - P=PASS F=FAILED

- ☒ SMOKE DETECTOR () OPERATIONAL () MISSING
- ☒ FLOORS () SOLID () WEAK () HOLES DAMAGED LOCATION _____
- ☒ DOORS () OPERABLE () DAMAGED
- ☒ WALLS () SOLID () STRUCTURALLY UNSOUND
- ☒ WINDOWS () OPERABLE () INOPERABLE
- ☒ PLUMBING FIXTURES () OPERABLE () INOPERABLE ☒ MISSING
- ☒ CEILING () SOLID () HOLES () LEAKS APPARENT
- ☒ ELECTRICAL (FIXTURES/OUTLETS) () OPERABLE ☒ EXPOSED WIRING ☒ OUTLET COVERS MISSING ☒ LIGHT
PICTURES MISSING

EXTERIOR:

- ☒ WALLS/SIDING () LOOSE SIDING () STRUCTURALLY UNSOUND () NOT WEATHERTIGHT () NEEDS CLEANING
- ☒ WINDOWS () CRACKED/BROKEN GLASS () SCREENS MISSING () WEATHERTIGHT
- ☒ ROOF () APPEARS SOLID () DAMAGED

STATUS

APPROVED ☒ WITH CONDITIONS: Repair exposed wiring, Replace Outlet Covers/missing

NOT APPROVED _____ NEED RE-INSPECTION FOR FOLLOWING CONDITIONS _____

SIGNATURE John R. Rul

402

6-12-09