

Britt Surveying and Mapping, LLC
1438 SW Main Boulevard • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

04/25/2022

Permit # 000043312

L-28527


Cornerstone Development

Re: Lot 9 Stonehenge Phase 2

To Whom It May Concern:

The top of the finished slab on Lot 9 is found to be 100.53 feet. The building permit shows the minimum floor elevation to be 101.8 feet (plat is in NGVD 29 datum) 100.99 feet NAVD 88. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,



L. Scott Britt
LS 5757

