



Britt Surveying and Mapping, LLC

1438 SW Main Blvd • Lake City, FL 32025

386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

12/13/2022

Permit # 000045796

L-29144

Re: 03114-138

Bradley Franks Construction

To Whom It May Concern:

The finished slab elevation is found to be 96.24 feet. The minimum floor elevation per the building permit is shown to be 95.5 feet. All elevations are shown in NAVD 88 datum.

Sincerely,

L. Scott Britt

LS 5757