



Load Short Form
Entire House
High Springs Electric

Job:
Date: Apr 26, 2024
By: Donna Brackeen
Plan: Suwannee Classic

Project Information

For: Salem/Russell Residence, Red Door Homes
 398 SW Sandersway, Fort White, FL

Design Information

	Htg	Clg	Method	Infiltration
Outside db (°F)	33	92		Simplified
Inside db (°F)	68	75	Construction quality	Average
Design TD (°F)	35	17	Fireplaces	0
Daily range	-	M		
Inside humidity (%)	50	50		
Moisture difference (gr/lb)	29	43		

HEATING EQUIPMENT

Make	Trane
Trade	TRANE
Model	4TWR4018G1
AHRI ref	212612025
Efficiency	7.5 HSPF2
Heating input	
Heating output	16800 Btuh @ 47°F
Temperature rise	0 °F
Actual air flow	0 cfm
Air flow factor	0 cfm/Btuh
Static pressure	0.50 in H2O
Space thermostat	
Capacity balance point = 34 °F	

COOLING EQUIPMENT

Make	Trane
Trade	TRANE
Cond	4TWR4018G1
Coil	TEM8A0B30V31++TDR
AHRI ref	212612025
Efficiency	11.7 EER2, 14.3 SEER2
Sensible cooling	13510 Btuh
Latent cooling	5790 Btuh
Total cooling	19300 Btuh
Actual air flow	643 cfm
Air flow factor	0.042 cfm/Btuh
Static pressure	0.50 in H2O
Load sensible heat ratio	0.86


ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
bd	237	3513	2508	0	105
bath	99	846	777	0	33
hall	37	0	0	0	0
wic	106	2245	1169	0	49
laundry	67	1259	1301	0	54
common	445	9416	9609	0	402

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Entire House	992	17279	15364	0	643
Other equip loads		0	0		
Equip. @ 0.97 RSM			14965		
Latent cooling			2491		
TOTALS	992	17279	17456	0	643

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.





16'-0"



Manual S Compliance Report

Entire House

High Springs Electric

Job:
 Date: Apr 26, 2024
 By: Donna Brackeen
 Plan: Suwannee Classic

Project Information

For: Salemi/Russell Residence, Red Door Homes
 398 SW Sandersway, Fort White, FL

Cooling Equipment

Design Conditions

Outdoor design DB:	92.4°F	Sensible gain:	15364	Btuh	Entering coil DB:	77.0°F
Outdoor design WB:	75.8°F	Latent gain:	2491	Btuh	Entering coil WB:	63.5°F
Indoor design DB:	75.0°F	Total gain:	17856	Btuh		
Indoor RH:	50%	Estimated airflow:	643	cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP					
Manufacturer:	Trane	Model:	4TWR4018G1+TEM8A0B30V31++TDR			
Actual airflow:	643	cfm				
Sensible capacity:	13510	Btuh	88% of load			
Latent capacity:	5790	Btuh	232% of load			
Total capacity:	19300	Btuh	108% of load	SHR:	70%	

Heating Equipment

Design Conditions

Outdoor design DB:	33.3°F	Heat loss:	17279	Btuh	Entering coil DB:	68.0°F
Indoor design DB:	68.0°F					

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP					
Manufacturer:	Trane	Model:	4TWR4018G1+TEM8A0B30V31++TDR			
Actual airflow:	0	cfm				
Output capacity:	16800	Btuh	97% of load			
Supplemental heat required:	479	Btuh				
			Capacity balance:	34 °F		
			Economic balance:	-99 °F		

Meets all requirements of ACCA Manual S.



Duct System Summary

Entire House

High Springs Electric

Job:
 Date: Apr 26, 2024
 By: Donna Brackeen
 Plan: Suwannee Classic

Project Information

For: Salem/Russell Residence, Red Door Homes
 398 SW Sandersway, Fort White, FL

	Heating	Cooling
External static pressure	0.50 in H2O	0.50 in H2O
Pressure losses	0.18 in H2O	0.18 in H2O
Available static pressure	0.32 in H2O	0.32 in H2O
Supply / return available pressure	0.196 / 0.124 in H2O	0.196 / 0.124 in H2O
Lowest friction rate	0.127 in/100ft	0.127 in/100ft
Actual air flow	0 cfm	643 cfm
Total effective length (TEL)		252 ft

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
bath	c 777	0	33	0.165	4.0	0x 0	VIFx	23.9	95.0	st2
bd	c 2508	0	105	0.166	6.0	0x 0	VIFx	23.3	95.0	st2
common	c 3204	0	134	0.148	7.0	0x 0	VIFx	27.6	105.0	st1
common-A	c 3203	0	134	0.127	7.0	0x 0	VIFx	44.2	110.0	st3
common-B	c 3203	0	134	0.128	7.0	0x 0	VIFx	43.4	110.0	st3
laundry	c 1301	0	54	0.159	4.0	0x 0	VIFx	18.1	105.0	st1
wic	c 1169	0	49	0.240	4.0	0x 0	VIFx	6.8	75.0	

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st1	Peak AVF	0	189	0.148	540	8.0	0 x 0	VinIFx	
st3	Peak AVF	0	268	0.127	491	10.0	0 x 0	VinIFx	st2
st2	Peak AVF	0	406	0.127	516	12.0	0 x 0	VinIFx	

Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb1	16x 13	0	457	65.1	0.191	581	12.0	0x 0		VIFx	
rb2	10x 9	0	186	97.7	0.127	534	8.0	0x 0		VIFx	