



Britt Surveying and Mapping, LLC

2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

9/02/2020

Permit # 000040227

Lot 41 Country Lake in Woodborough Phase 2

L-26911

Bryan Zecher Construction

To whom it may concern,

The elevation of the top of the slab on said lot 41 is found to be 138.63 feet. The minimum floor elevation is shown to be 137.5 feet per the permit.

Sincerely,

L. Scott Britt
LS 5757