

STATE OF FLORIDA
DEPARTMENT OF HEALTH
APPLICATION FOR CONSTRUCTION PERMIT


Permit Application Number

13-0547

----- PART II - SITEPLAN -----

Scale: Each block represents 10 feet and 1 inch = 40 feet.

1 Acre of 31 acres



Notes:

Elizabeth Williams

31.00 acres

24-45-17-08719-001

Site Plan submitted by:

Robert W. Juel

10/15/13

Plan Approved

Not Approved

Date 10/30/13

By

Columbo

County Health Department

ALL CHANGES MUST BE APPROVED BY THE COUNTY HEALTH DEPARTMENT

DH 4015, 08/08 (Obsolesces previous editions which may not be used) Incorporated: 84E-6.001, PAC
(Stock Number: 5744-002-4015-6)

Page 2 of 4



STATE OF FLORIDA
DEPARTMENT OF HEALTH
ONSITE SEWAGE TREATMENT AND DISPOSAL
SYSTEM
APPLICATION FOR CONSTRUCTION PERMIT

PERMIT NO. 13-1547
DATE PAID: 10/16/13
FEE PAID: 318.88
RECEIPT #: 1123507

APPLICATION FOR:

☒ New System ☐ Existing System ☐ Holding Tank ☐ Innovative
☐ Repair ☐ Abandonment ☐ Temporary ☐ _____

APPLICANT: Elizabeth J. Williamson (Trent Giesler)
AGENT: Robert Ford NFST, INC TELEPHONE: 755-6372
MAILING ADDRESS: 580 NW Everdon St LC FL 32055

TO BE COMPLETED BY APPLICANT OR APPLICANT'S AUTHORIZED AGENT. SYSTEMS MUST BE CONSTRUCTED BY A PERSON LICENSED PURSUANT TO 489.103(3) (a) OR 489.552, FLORIDA STATUTES. IT IS THE APPLICANT'S RESPONSIBILITY TO PROVIDE DOCUMENTATION OF THE DATE THE LOT WAS CREATED OR PLATTED (MM/DD/YY) IF REQUESTING CONSIDERATION OF STATUTORY GRANDFATHER PROVISIONS.

PROPERTY INFORMATION

LOT: 1 BLOCK: 1 SUBDIVISION: 24-48-17 PLATTED: _____

PROPERTY ID #: 08719-001 ZONING: _____ I/M OR EQUIVALENT: ☒ Y ☐ N

PROPERTY SIZE: 31 ACRES WATER SUPPLY: ☒ PRIVATE PUBLIC ☐ ☐ <2000GPD ☐ >2000GPD

IS SEWER AVAILABLE AS PER 381.0065, FSP? ☒ Y ☐ N DISTANCE TO SEWER: 118 FT

PROPERTY ADDRESS: 4277 SE Cr 252 LC FL 32055

DIRECTIONS TO PROPERTY: Hwy 100 East to Price Creek (245) TR
Follow to 252 TL 1st Drive on Right

BUILDING INFORMATION

☒ RESIDENTIAL☐ COMMERCIAL

Unit No	Type of Establishment	No. of Bedrooms	Building Area Sqft	Commercial/Institutional System Design Table 1, Chapter 64E-6, FAC
1	<u>S/E House</u>	<u>2</u>	<u>988</u>	
2				
3				
4				

☐ Floor/Equipment Drains ☐ Other (Specify) _____

SIGNATURE: Robert W. Ford DATE: 10/15/13



STATE OF FLORIDA
DEPARTMENT OF HEALTH
ONSITE SEWAGE TREATMENT AND DISPOSAL SYSTEM
CONSTRUCTION PERMIT

PERMIT #: **12-SC-1500692**
APPLICATION #: **AP1123507**
DATE PAID: **10/24/13**
FEE PAID: **310.00**
RECEIPT #: **228819**
DOCUMENT #: **PR920801**

CONSTRUCTION PERMIT FOR: OSTDS New

APPLICANT: ELIZABETH*13-0547 WILLIAMSON

PROPERTY ADDRESS: 4277 SE CR 252 Lake City, FL 32055

LOT: _____ BLOCK: _____ SUBDIVISION: _____

PROPERTY ID #: 08719-001 [SECTION, TOWNSHIP, RANGE, PARCEL NUMBER]
(OR TAX ID NUMBER)

SYSTEM MUST BE CONSTRUCTED IN ACCORDANCE WITH SPECIFICATIONS AND STANDARDS OF SECTION 381.0065, F.S., AND CHAPTER 64E-6, F.A.C. DEPARTMENT APPROVAL OF SYSTEM DOES NOT GUARANTEE SATISFACTORY PERFORMANCE FOR ANY SPECIFIC PERIOD OF TIME. ANY CHANGE IN MATERIAL FACTS, WHICH SERVED AS A BASIS FOR ISSUANCE OF THIS PERMIT, REQUIRE THE APPLICANT TO MODIFY THE PERMIT APPLICATION. SUCH MODIFICATIONS MAY RESULT IN THIS PERMIT BEING MADE NULL AND VOID. ISSUANCE OF THIS PERMIT DOES NOT EXEMPT THE APPLICANT FROM COMPLIANCE WITH OTHER FEDERAL, STATE, OR LOCAL PERMITTING REQUIRED FOR DEVELOPMENT OF THIS PROPERTY.

SYSTEM DESIGN AND SPECIFICATIONS

T [900] GALLONS / GPD Septic CAPACITY
A [] GALLONS / GPD N/A CAPACITY
N [] GALLONS GREASE INTERCEPTOR CAPACITY [MAXIMUM CAPACITY SINGLE TANK 1250 GALLONS]
K [] GALLONS DOSING TANK CAPACITY [] GALLONS @ [] DOSES PER 24 HRS #Pumps []

D [250] SQUARE FEET Drainfield SYSTEM
R [] SQUARE FEET N/A SYSTEM

A TYPE SYSTEM: [] STANDARD [] FILLED [x] MOUND []
I CONFIGURATION: [x] TRENCH [] BED []

F LOCATION OF BENCHMARK: Nail with pink green ribbon 24" tree

E ELEVATION OF PROPOSED SYSTEM SITE [36 00] [INCHES] FT [] ABOVE [] BELOW BENCHMARK/REFERENCE POINT

E BOTTOM OF DRAINFIELD TO BE [32 00] [INCHES] FT [] ABOVE [] BELOW BENCHMARK/REFERENCE POINT

L
D FILL REQUIRED: [22.00] INCHES EXCAVATION REQUIRED: [0 00] INCHES

O The system is sized for 2 bedrooms with a maximum occupancy of 4 persons (2 per bedroom), for a total estimated flow of 200 gpd
T The licensed contractor installing the system is responsible for installing the minimum category of tank in accordance with
H s 64E-6.013(3)(f), FAC.

SPECIFICATIONS BY: Robert W Ford TITLE: Master Contractor

APPROVED BY: Jeremy K Gifford TITLE: Environmental Specialist I Columbia CHD

DATE ISSUED: 10/30/2013 EXPIRATION DATE: 04/30/2015

DH 4016, 08/09 (Obsoletes all previous editions which may not be used)
Incorporated: 64E-6.003, FAC

Page 1 of 3

v 1 1 4

AP1123507

SE911609