J-11951 - C-1309 Job: Date: May 08, 2025 LaNiika Stewart

Project Information

IC/GOODSON RESIDENCE For:

337 SW Tompkins St, Lake City, FL 32024

Notes:

Design Information

Weather: Gainesville, FL, US

Winter Design Conditions

Summer Design Conditions

| Outside db Inside db | 33 °F 70 °F | Outside db Inside db | 92 °F 75 °F |
|-------------------------|----------------|---------------------------------------|------------------|
| Design TD | 37 °F | Design TD Daily range | 17 °F M |
| Ventilation Method | MJ8 | Relative humidity Moisture difference | 50 % 43 gr/lb |

Heating Summary

Sensible Cooling Equipment Load Sizing

| Structure Ducts (R-6.0) Central vent (0 cfm) | 35354 7868 0 | | Structure Ducts (R-6.0) Central vent (0 cfm) | 27633 10993 0 | |
|--|--------------------|--------------|---|---------------------|------|
| Humidification Piping | 0 | Btuh Btuh | Blower | 0 | Btuh |
| Piping Equipment load | 43222 | Btuh | Use manufacturer's data | n | |
| Infiltration | | | Rate/swing multiplier Equipment sensible load | 0.97 37621 | Btuh |

Simplified Average 0 Construction quality

Latent Cooling Equipment Load Sizing Structure 2480 Btuh

| | | | Ducts Central vent (0 cfm) | 2264 Btuh 0 Btuh | |
|------------------|-----------------|-----------------|---------------------------------|---------------------|--|
| Area (ft²) | Heating 2624 | Cooling 2624 | Equipment latent load | 4744 Btuh | |
| Volume (ft³) | 26500 | 26500 | _4-4-4 | | |
| Air changes/hour | 0.32 | 0.16 | Equipment Total Load (Sen+Lat) | 42365 Btuh | |
| Equiv. AVF (cfm) | 141 | 71 | Reg. total capacity at 0.80 SHR | 3.9 ton | |

Heating Equipment Summary

Input = 13 kW, Output = 43511 Btuh, 100 AFUE

Cooling Equipment Summary

| Make Trade Model AHRI ref | Trane TRANE 5TWR5048A1000A | | | Make Trade Cond Coil AHRI ref | Trane TRANE 5TWR5048 5TEM4D06 | | | |
|--|----------------------------------|------------------------------|--|--|--|---------------|---|-----------------------------|
| Efficiency Heating input Heating output Temperature Actual air flo Air flow facto Static pressi Space therm Capacity bal | out e rise ov or ure | 43500 26 1500 0.035 | HSPF2 Btuh @ 47°F °F cfm cfm/Btuh in H2O | Efficiency Sensible cor Latent cooling Total cooling Actual air flo Air flow facto Static press Load sensib | ng J w or ure | 12.0 EER2, 10 | 36000 9000 45000 1500 0.039 | Btuh Btuh Btuh cfm |
| Pookup: | | | | | | | | |

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Method

Fireplaces

Job: J-11951 - C-1309 Date: May 08, 2025

LaNiika Stewart

Project Information

IC/GOODSON RESIDENCE For:

337 SW Tompkins St, Lake City, FL 32024

Cooling Equipment

Design Conditions

| Outdoor design DB: | 92.4°F | Sensible gain: | 38626 | Btuh | Entering coil DB: | 78.3°F |
|--------------------|--------|--------------------|-------|------|-------------------|--------|
| Outdoor design WB: | 75.8°F | Latent gain: | 4744 | Btuh | Entering coil WB: | 64.1°F |
| Indoor design DB: | 75.0°F | Total gain: | 43369 | Btuh | _ | |
| Indoor RH: | 50% | Estimated airflow: | 1500 | cfm | | |

Manufacturer's Performance Data at Actual Design Conditions

Split ASHP Equipment type:

Manufacturer: Trane Model: 5TWR5048A1000A+5TEM4D06AC41SA

Actual airflow: 1500 cfm

101% of load Sensible capacity: 38930 Btuh 112% of load Latent capacity: 5316 Btuh

Total capacity: 44246 102% of load SHR: 88% Btuh

Heating Equipment

Design Conditions

Outdoor design DB: 33.3°F Heat loss: 43222 Btuh Entering coil DB: 68.4°F

Indoor design DB: 70.0°F

Manufacturer's Performance Data at Actual Design Conditions

Split ASHP Equipment type:

Manufacturer: Trane Model: 5TWR5048A1000A+5TEM4D06AC41SA

Actual airflow: 1500 cfm

Output capacity: 34093 Btuh 79% of load Capacity balance: 33 °F 9129 Economic balance: Supplemental heat required: Btuh -99 °F

Backup equipment type: Elec strip

Manufacturer: Model:

Actual airflow: 1500 cfm

50 °F Output capacity: 12.8 kW 101% of load Temp. rise:

Meets all requirements of ACCA Manual S.