



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

12/06/20021

Permit # 000042581

L-28182

Lipscomb & Eagle

Re: Lot 22 Turkey Creek, Unit 1

To Whom It May Concern:

The top of the finished slab on said parcel is 158.54 feet. The required finished floor elevation is 161.25 feet per the building permit. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,


L. Scott Britt
LS 5757

