

39669

SCHAFFER ENGINEERING, LLC ca 9312

14705 Main Street, Alachua, FL 32615 PH: 386-462-1340

June 17, 2020

Job: DWC Contracting

Re: 14'-4" Lanai Header \ 16' Garage Header


Dear Sir:

After the review of the truss layout it was determined that the (2) ply 2 x 12 syp #2 with a 7/16 osb spacer will be sufficient for the 14'-4" rear lanai header span.

The B1GE Gable end truss is bearing across a 16'-0" (2) ply 2 x 12 syp #2 with a 7/16 osb spacer. After the review this header was also determined to be acceptable.

If you have any questions or if we can be any further assistance, please feel free to contact us at your convenience.




6-18-20
Bruce Schafer, P.E. #48984
7104 N. W. 42nd Lane
Gainesville, Florida 32606

(Sealed)