

CAROL CHADWICK, P.E.

*Civil Engineer*

1208 S.W. Fairfax Glen

Lake City, FL 32025

307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com

May 19, 2023

Mr. Buddy Scott

386.365.1222

wscottconstruction@gmail.com

re: ANCHOR BOLT WASHERS: 8803 SE CR 245, LAKE CITY, FL

The required 3" x 3" x 1/8" washer may be replaced with 2" x 2" x 1/8" washers.

In my professional opinion, this structure meets the structural load and uplift requirement for a residential dwelling per the Florida Building Code 2020, 7<sup>th</sup> Edition, Residential. Should you have any questions, please don't hesitate to contact me.

Respectfully,

Carol Chadwick, P.E.



Digitally signed  
by Carol  
Chadwick  
DN: c=US,  
o=Florida,  
dnQualifier=A014  
10D0000017EB6D  
924CE0005954C,  
cn=Carol  
Chadwick  
Date: 2023.05.19  
11:06:20 -04'00'

Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

CC Job #FL22118