



STATE OF FLORIDA
DEPARTMENT OF HEALTH
ONSITE SEWAGE TREATMENT AND DISPOSAL
SYSTEM

PERMIT #: 12-SC-3151985
APPLICATION #: AP2226946
DATE PAID:
FEE PAID:
RECEIPT #:
DOCUMENT #: PR2281890

CONSTRUCTION PERMIT FOR: OSTDS New
APPLICANT: FOREST**25-0535 LAND DEV LLC
PROPERTY ADDRESS: SW CADENCE Gln Lake City, FL 32055
LOT: 8
BLOCK:
SUBDIVISION: FOREST COVE
PROPERTY ID #: 03001-108
[SECTION, TOWNSHIP, RANGE, PARCEL NUMBER]
[OR TAX ID NUMBER]

SYSTEM MUST BE CONSTRUCTED IN ACCORDANCE WITH SPECIFICATIONS AND STANDARDS OF SECTION 381.0065, F.S., AND CHAPTER 64E-6, F.A.C. DEPARTMENT APPROVAL OF SYSTEM DOES NOT GUARANTEE SATISFACTORY PERFORMANCE FOR ANY SPECIFIC PERIOD OF TIME. ANY CHANGE IN MATERIAL FACTS, WHICH SERVED AS A BASIS FOR ISSUANCE OF THIS PERMIT, REQUIRE THE APPLICANT TO MODIFY THE PERMIT APPLICATION. SUCH MODIFICATIONS MAY RESULT IN THIS PERMIT BEING MADE NULL AND VOID. ISSUANCE OF THIS PERMIT DOES NOT EXEMPT THE APPLICANT FROM COMPLIANCE WITH OTHER FEDERAL, STATE, OR LOCAL PERMITTING REQUIRED FOR DEVELOPMENT OF THIS PROPERTY.

SYSTEM DESIGN AND SPECIFICATIONS

T 900] GALLONS / GPD New Multi-Chambered Septic CAPACITY
A 900] GALLONS / GPD N/A CAPACITY
N 900] GALLONS GREASE INTERCEPTOR CAPACITY [MAXIMUM CAPACITY SINGLE TANK:1250 GALLONS]
K 900] GALLONS DOSING TANK CAPACITY [] GALLONS @ [] DOSES PER 24 HRS #Pumps []
D 375] SQUARE FEET Drainfield SYSTEM
R 375] SQUARE FEET N/A SYSTEM
A TYPE SYSTEM: [] STANDARD [] FILLED [] MOUND []
I CONFIGURATION: [] TRENCH [] BED []
N LOCATION OF BENCHMARK: Nail in oak S of site
F ELEVATION OF PROPOSED SYSTEM SITE [12.00] [INCHES] [FT] [ABOVE / BELOW] BENCHMARK/REFERENCE POINT
E BOTTOM OF DRAINFIELD TO BE [42.00] [INCHES] [FT] [ABOVE / BELOW] BENCHMARK/REFERENCE POINT
D FILL REQUIRED: [0.00] INCHES EXCAVATION REQUIRED: [] INCHES

The system is sized for 4 bedrooms with a maximum occupancy of 8 persons (2 per bedroom), for a total estimated flow of 400 gpd.

SPECIFICATIONS BY: William D Bishop II
TITLE: Master Septic Contractor
APPROVED BY: Sean P Havens
DATE ISSUED: 09/08/2025
EXPIRATION DATE: 12/27/2026
Columbia CHD

DEP 4015, 06-21-2022 (Obsoletes previous editions which may not be used)
Incorporated 62-6.004, FAC

