

INSPECTION DAILY REPORT

No.: _____

PAGE: 1 OF 1

0215.1900017.000

PROJECT NO.: lot 43-Rolling Meadows

DATE: 12-26-2019

PROJECT NAME: Sparks Construction

TIME ON SITE: 1 Hr

PROJECT LOCATION: 279 SW Buttercup Dr.

TRAVEL TIME: 2 Hr

CLIENT: Lake City, FL

WEATHER: Sunny

PERMIT AGENCY: Sparks Construction

TEMPERATURE: 74°

PERMIT NO.: Columbia County

UES INSPECTOR: 38972

APPLICABLE PERSONNEL ON SITE / COMPANY:

APPLICABLE PLANS USED FOR INSPECTION:

N/A.

APPROVED PLANS

ELEMENTS INSPECTED: SIAB — Approved

FIELD OBSERVATIONS (NUMBER EACH ITEM):

- 1.) OBSERVED SIAB PREP PRIOR TO CONCRETE PLACEMENT.
 - A.) WLM INSTALLED WITH PROPER SUPPORT (MESH-UPS)
 - B.) INTERIOR FOOTING INSTALLED @ NW END FOR BEARING - PER TRUSS LAYOUT.



THE ABOVE REFERENCED CONSTRUCTION WAS NOTED IN PLACE IN SUBSTANTIAL CONFORMANCE TO THE PLANS AND SPECIFICATIONS, EXCEPT AS NOTED HEREIN.



Universal Engineering Sciences, Inc.

4475 SW 35th Terrace Gainesville, FL 32608

(352) 372-3392

Fax (352) 336-7914

