

# COLUMBIA COUNTY BUILDING DEPARTMENT RESIDENTIAL CHECK LIST

MINIMUM PLAN REQUIREMENTS: FLORIDA BUILDING CODE RESIDENTIAL 2017 EFFECTIVE 1 JANUARY 2018
AND THE NATIONAL ELECTRICAL 2014 EFFECTIVE 1 JANUARY 2018

#### ALL REQUIREMENTS ARE SUBJECT TO CHANGE

ALL BUILDING PLANS MUST INDICATE COMPLIANCE WITH THE CURRENT FLORIDA BUILDING CODES RESIDENTIAL AND THE NATIONAL ELECTRICAL CODE. ALL PLANS OR DRAWINGS SHALL PROVIDE CALCULATIONS AND DETAILS THAT HAVE THE SEAL AND SIGNATURE OF A CERTIFIED ARCHITECT OR ENGINEER REGISTERED IN THE STATE OF FLORIDA, OR ALTERNATE METHODOLOGIES, APPROVED BY THE STATE OF FLORIDA BUILDING COMMISSION FOR ONE-AND-TWO FAMILY DWELLINGS, FBC 1609.3.1 THRU 1609.3.3.

FOR DESIGN PURPOSES THE FOLLOWING BASIC WIND SPEEDS ARE PER FLORIDA BUILDING CODE FIGURE 1609-A
THROUGH 1609-C ULTIMATE DESIGN WIND SPEEDS FOR RISK CATEGORY AND BUILDINGS AND OTHER STRUCTURES
Revised 7/1/18

		GENERAL REQUI	yfla.com/BuildingandZoning.asp REMENTS: CABLE BOXES BEFORE SUBMITTAL	Each Box shall be Circled as Applicable			
				Sele	ct Fr	om Drop	down
1	Two (2) complete sets of pla	ans containing the follow	wing:	V			
2	All drawings must be clear,	concise, drawn to scale	, details that are not used shall be marked void	V			
3	Condition space (Sq. Ft.)		Total (Sq. Ft.) under roof	Y	es	No	NA
				•			

Designers name and signature shall be on all documents and a licensed architect or engineer, signature and official embossed seal shall be affixed to the plans and documents as per the FLORIDA BUILDING CODES RESIDENTIAL 107.1.

Site Plan information including:

19

20

Number of stories

4	Dimensions of lot or parcel of land	Yes	
5	Dimensions of all building set backs	Yes	
6	Location of all other structures (include square footage of structures) on parcel, existing or proposed well and septic tank and all utility easements.	Yes	
7	Provide a full legal description of property.	Yes	

### Wind-load Engineering Summary, calculations and any details are required.

Building height from the established grade to the roofs highest peak

	GENERAL REQUIREMENTS: APPLICANT – PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL	Items to Includ Each Box shall Circled as Applicable		ll be
8	Plans or specifications must show compliance with FBCR Chapter 3	Yes	No	NA
		Select Fr	om Drop	down
9	Basic wind speed (3-second gust), miles per hour	Yes		
10	(Wind exposure – if more than one wind exposure is used, the wind exposure and applicable wind direction shall be indicated)	Yes		
11	Wind importance factor and nature of occupancy	Yes		
12	The applicable internal pressure coefficient, Components and Cladding	Yes		
13	The design wind pressure in terms of psf (kN/m²), to be used for the design of exterior component, cladding materials not specifally designed by the registered design professional.	Yes		
Ele	evations Drawing including:			
14	All side views of the structure	Yes		
15	Roof pitch	Yes		
16	Overhang dimensions and detail with attic ventilation	Yes		
17	Location, size and height above roof of chimneys	NA		
18	Location and size of skylights with Florida Product Approval	NA		

Yes

Yes

Floor Plan Including:

21	Dimensioned area plan showing rooms, attached garage, breeze ways, covered porches, deck, balconies	Yes	
22	Raised floor surfaces located more than 30 inches above the floor or grade	Yes	
23	All exterior and interior shear walls indicated	Yes	
24	Shear wall opening shown (Windows, Doors and Garage doors)	Yes	
25	Show compliance with Section FBCR 310 Emergency escape and rescue opening shown in each		
	bedroom (net clear opening shown) and Show compliance with Section FBC 1405.13.2 where the opening of an operable window is located more than 72 inches above the finished grade or surface below, the lowest part of the clear opening of the window shall be a minimum of 24 inches above the finished floor of the room in which the window is located. Glazing between the floor and 24 inches shall be fixed or have openings through which a 4-inch-diameter sphere cannot pass.	Yes	
26	Safety glazing of glass where needed	Yes	
27	Fireplaces types (gas appliance) (vented or non-vented) or wood burning with Hearth (see chapter 10 and chapter 24 of FBCR)	NA	
28	Show stairs with dimensions (width, tread and riser and total run) details of guardrails, Handrails	Yes	
29	Identify accessibility of bathroom (see FBCR SECTION 320)	Yes	

All materials placed within opening or onto/into exterior walls, soffits or roofs shall have Florida product approval number and mfg. installation information submitted with the plans (see Florida product approval form)

GENERAL REQUIREMENTS:	Items to Include-
APPLICANT – PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL	Each Box shall be Circled as
	Applicable

### **FBCR 403: Foundation Plans**

Select 1	From	Drop	down
.,			

	Total and the second se		 · · ·
30	Location of all load-bearing walls footings indicated as standard, monolithic, dimensions, size and type of reinforcing.	Yes	
31	All posts and/or column footing including size and reinforcing	Yes	
32	Any special support required by soil analysis such as piling.	Yes	
33	Assumed load-bearing valve of soil Pound Per Square Foot	Yes	
34	Location of horizontal and vertical steel, for foundation or walls (include # size and type) For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an grounding electrode system. Per the National Electrical Code article 250.52.3	Yes	

## FBCR 506: CONCRETE SLAB ON GRADE

<b>3</b> 5	Show Vapor retarder (6mil. Polyethylene with pints la pd 6 inches and sealed)	Yes		
36	Show control j oints, synthetic fiber reinforcement or welded fire fabric reinforcement and Supprts	Yes	100	ĺ

### **FBCR 318: PROTECTION AGAINST TERMITES**

	Indicate on the foundation plan if soil treatment is used for subterranean termite prevention or		
37	Submit other approved termite protection methods. Protection shall be provided by registered termiticides	Yes	

### FBCR 606: Masonry Walls and Stem walls (load bearing & shear Walls)

38 Show all materials making up walls, wall height, and Block size, mortar type	Yes	
39 Show all Lintel sizes, type, spans and tie-beam sizes and spacing of reinforcement	Yes	

Metal frame shear wall and roof systems shall be designed, signed and sealed by Florida Prof. Engineer or Architect

Floor Framing System: First and/or second story

	Floor truss package shall including layout and details, signed and sealed by Florida Registered	Yes	
40	Professional Engineer	163	
41	Show conventional floor joist type, size, span, spacing and attachment to load bearing walls, stem walls and/or priers	Yes	
42	Girder type, size and spacing to load bearing walls, stem wall and/or priers	Yes	
43	Attachment of joist to girder	Yes	
44	Wind load requirements where applicable	Yes	
45	Show required under-floor crawl space	NA	
46	Show required amount of ventilation opening for under-floor spaces	NA	
47	Show required covering of ventilation opening	Yes	
48	Show the required access opening to access to under-floor spaces	NA	
49	Show the sub-floor structural panel sheathing type, thickness and fastener schedule on the edges & intermediate of the areas structural panel sheathing	NA	
50	Show Draftstopping, Fire caulking and Fire blocking	Yes	
51	Show fireproofing requirements for garages attached to living spaces, per FBCR section 302.6	Yes	
52	Provide live and dead load rating of floor framing systems (psf).	Yes	

FBCR CHAPTER 6 WOOD WALL FRAMING CONSTRUCTION

**GENERAL REQUIREMENTS:** 

	APPLICANT – PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL	Circled Applical	as
	Se	elect from Dr	op down
53	Stud type, grade, size, wall height and oc spacing for all load bearing or shear walls	Yes	
54	Fastener schedule for structural members per table FBC-R602.3.2 are to be shown	Yes	
55	Show wood structural panel's sheathing attachment to studs, joist, trusses, rafters and structural members, showing fastener schedule attachment on the edges & intermediate of the areas structural panel sheathing	Yes	
56	Show all required connectors with a max uplift rating and required number of connectors and oc spacing for continuous connection of structural walls to foundation and roof trusses or rafter systems	Yes	
57	Show sizes, type, span lengths and required number of support jack studs, king studs for shear wall opening and girder or header per FBC-R602.7.	Yes	
58	Indicate where pressure treated wood will be placed	Yes	
59	Show all wall structural panel sheathing, grade, thickness and show fastener schedule for structural panel sheathing edges & intermediate areas	Yes	
60	A detail showing gable truss bracing, wall balloon framing details or/ and wall hinge bracing detail	Yes	

# **FBCR: ROOF SYSTEMS:**

61	Truss design drawing shall meet section FBC-R 802.10. 1 Wood trusses	Yes	
62	Include a layout and truss details, signed and sealed by Florida Professional Engineer	Yes	
63	Show types of connector's assemblies' and resistance uplift rating for all trusses and rafters	Yes	
64	Show gable ends with rake beams showing reinforcement or gable truss and wall bracing details	Yes	
65	Provide dead load rating of trusses	Yes	

# FBCR 802:Conventional Roof Framing Layout

66	Rafter and ridge beams sizes, span, species and spacing	Yes	
67	Connectors to wall assemblies' include assemblies' resistance to uplift rating	Yes	
68	Valley framing and support details	Yes	
69	Provide dead load rating of rafter system	Yes	

### **FBCR 803 ROOF SHEATHING**

70	Include all materials which will make up the roof decking, identification of structural panel sheathing, grade, thickness	Yes	
71	Show fastener Size and schedule for structural panel sheathing on the edges & intermediate areas	Yes	

Items to Include-

Each Box shall be

**ROOF ASSEMBLIES FRC Chapter 9** 

72	Include all materials which will make up the roof assembles covering	Yes	
73	Submit Florida Product Approval numbers for each component of the roof assembles covering	Yes	

# FBCR Chapter 11 Energy Efficiency Code for Residential Building

**GENERAL REQUIREMENTS:** 

Residential construction shall comply with this code by using the following compliance methods in the FBCR Chapter 11 Residential buildings compliance methods. Two of the required forms are to be submitted, N1100.1.1.1 As an alternative to the computerized Compliance Method A, the Alternate Residential Point System Method hand calculation, Alternate Form 600A, may be used. All requirements specific to this calculation are located in Sub appendix C to Appendix G. Buildings complying by this alternative shall meet all mandatory requirements of this chapter. Computerized versions of the Alternate Residential Point System Method shall not be acceptable for code compliance.

	APPLICANT – PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL	Circled as Applicable	
	S	elect from Drop	
74	Show the insulation R value for the following areas of the structure	Yes	
75	Attic space	Yes	
	Exterior wall cavity	Yes	
77	Crawl space	NA	
н	AC information		
78	Submit two copies of a Manual J sizing equipment or equivalent computation study	Yes	
79	Exhaust fans shown in bathrooms Mechanical exhaust capacity of 50 cfm intermittent or 20 cfm continuous required	Yes	
30	Show clothes dryer route and total run of exhaust duct	Yes	
Ρh	imbing Fixture layout shown		
	All fixtures waste water lines shall be shown on the foundationplan	Yes	2
32	•	Yes	
	vate Potable Water		90.00
	Pump motor horse power	Yes	6.
	Reservoir pressure tank gallon capacity	Yes	
35	Rating of cycle stop valve if used	Yes	
Ele	ectrical layout shown including		
86	Show Switches, receptacles outlets, lighting fixtures and Ceiling fans	Yes	
87	Show all 120-volt, single phase, 15- and 20-ampere branch circuits outlets required to be protected by Ground-Fault Circuit Interrupter (GFCI) Article 210.8 A	Yes	
88	Show the location of smoke detectors & Carbon monoxide detectors	Yes	
89	Show service panel, sub-panel, location(s) and total ampere ratings	Yes	
90	On the electrical plans identify the electrical service overcurrent protection device for the main electrical service. This device shall be installed on the exterior of structures to serve as a disconnecting means for the utility company electrical service. Conductors used from the exterior disconnecting means to a panel or sub panel shall have four-wire conductors, of which one conductor shall be used as an equipment ground. Indicate if the utility company service entrance cable will be of the overhead or underground type.	Yes	
	For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an Grounding electrode system. Per the National Electrical Code article 250.52.3		
91	Appliances and HVAC equipment and disconnects	Yes	
92	Show all 120-volt, single phase, 15- and 20-ampere branch circuits supplying outlets installed in dwelling unit family rooms, dining rooms, living rooms, parlors, libraries, dens, bedrooms, sunrooms, recreation rooms, closets, hallways, or similar rooms or areas shall be protected by a listed <b>Combination arc-fault circuit interrupter</b> , Protection device.	Yes	

Items to Include-

Each Box shall be

### **Notice Of Commencement:**

A notice of commencement form RECORDED in the Columbia County Clerk Office is required to be filed with the Building Department BEFORE ANY INSPECTIONS can be performed.

CENTRAL PROLUMENTATION	Items to Include-
GENERAL REQUIREMENTS: APPLICANT – PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL	Each Box shall be Circled as
	Applicable

# \*\*ITEMS 95, 96, & 98 Are Required After APPROVAL from the ZONING DEPT.\*\*

Select from Drop down

	Se Se	lect from	Drop	aowr
93	<b>Building Permit Application</b> A current Building Permit Application is to be completed, by following the Checklist all supporting documents must be submitted.  There is a \$15.00 application fee. The completed application with attached documents and application fee can be mailed.	Yes		
94	Parcel Number The parcel number (Tax ID number) from the Property Appraisers Office (386) 758-1083 is required. A copy of property deed is also required. www.columbiacountyfla.com	Yes		# <del>24/1</del>
95	Environmental Health Permit or Sewer Tap Approval A copy of a approved Columbia County Environmental Health (386) 758-1058	Yes		
96	City of Lake City A City Water and/or Sewer letter. Call 386-752-2031	NA		
97	Toilet facilities shall be provided for all construction sites	]-		
98	<b>Town of Fort White</b> (386) 497-2321 If the parcel in the application for building permit is within the Corporate city limits of Fort White, an approval land use development letter issued by the Town of Fort is required to be submitted with the application for a building permit.	NA		
99	Flood Information: All projects within the Floodway of the Suwannee or Santa Fe Rivers shall require permitting through the Suwannee River Water Management District, before submitting a application to this office. Any project located within a flood zone where the base flood elevation (100 year flood) has been established shall meet the requirements of Section 8.5.2 of the Columbia County Land Development Regulations. Any project located within a flood zone where the base flood elevation has not been established (Zone A) shall meet the requirements of Section 8.5.3 of the Columbia County Land Development Regulations (Municode.com)	NA		
100	CERTIFIED FINISHED FLOOR ELEVATIONS will be required on any project where the approved FIRM Flood Maps show the property is in a AE, Floodway, and AH flood zones. Additionally One Foot Rise letters are required for AE and AH zones. In the Floodway Flood zones a Zero Rise letter is required.	NA		
101	A Flood development permit is also required for AE, Floodway & AH. Development permit cost is \$50.00	NA		
102	<b>Driveway Connection:</b> If the property does not have an existing access to a public road, then an application for a culvert permit (\$25.00) must be made. County Public Works Dept. determines the size and length of every culvert before instillation and completes a final inspection before permanent power is granted. If the applicant feels that a culvert is not needed, they may apply for a culvert waiver (\$50.00) Separate Check when issued. If the project is to be located on an F.D.O.T. maintained road, then an F.D.O.T. access permit is required.	Yes		
103	911 Address: An application for a 911 address must be applied for and received through the Columbia County Emergency Management Office of 911 Addressing Department (386) 758-1125.	No		

Ordinance Sec. 90-75. - Construction debris. (e) It shall be unlawful for any person to dispose of or discard solid waste, including construction or demolition debris at any place within the county other than on an authorized disposal site or at the county's solid waste facilities. The temporary storage, not to exceed seven days of solid waste (excluding construction and demolition debris) on the premises where generated or vegetative trash pending disposition as authorized by law or ordinance, shall not be deemed a violation of this section. The temporary storage of construction and demolition debris on the premises where generated or vegetative trash pending disposition as authorized by law or ordinance shall not be deemed in violation of this section; provided, however, such construction and demolition debris must be disposed of in accordance with this article prior to the county's issuance of a certificate of occupancy for the premises. The burning of lumber from a construction or demolition project or vegetative trash when done so with legal and proper permits from the authorized agencies and in accordance with such agencies' rules and regulations, shall not be deemed a violation of this section. No person shall bury, throw, place, or deposit, or cause to be buried, thrown, placed, or deposited, any solid waste, special waste, or debris of any kind into or on any of the public streets, road right-of-way, highways, bridges, alleys, lanes, thoroughfares, waters, canals, or vacant lots or lands within the county. No person shall bury any vegetative trash on any of the public streets, road right-of-way, highways, bridges, lanes, thoroughfares, waters, canals, or lots less than ten acres in size within the county.