



---

**Britt Surveying and Mapping, LLC**

2086 SW Main Blvd Ste 112 • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

07/08/2021

Permit # 000046686 \40157

L-27661

Travis Hart

Re: Lot 69 & part of Lot 68 Santa Fe River Plantations Replat of Lots 38, 45 & 46

To Whom It May Concern:

The top of the finished slab on said Lot 69 is 56.85 feet. The building permit requires the minimum floor to be 46 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,

  
L. Scott Britt  
LS 5757