

From: [Daina A. Woodman](#)
To: [Melissa Garber](#)
Cc: [Marshall McElroy](#)
Subject: RESULT: Jewel Lake
Date: Thursday, February 17, 2022 9:35:09 AM

Hi Melissa, Please see below results.

Permit Number: 42784, 283 SW Jewel Lake Drive Lot 42

Date for inspection: 2/16/2022

Contact Phone: 3524432412

Instructions: Roof Underlayment and Dry In : **PASS (MMCELROY)**

No Flashing Installed at the time of inspection. Concealed Fasteners not inspected.

Requested Inspections:

Building - Roof Decking

Permit Number: 42787, 265 SW Jewel Lake Drive Lot 43

Date for inspection: 2/16/2022

Contact Phone: 3524432412

Instructions: Roof Underlayment and Dry In : **PASS (MMCELROY)**

No Flashing Installed at the time of inspection.

Requested Inspections:

Building - Roof Decking

Thank you,

Daina A. Woodman

Building Inspections Department, Gainesville Office

4475 SW 35th Terrace, Gainesville, FL 32608

Cell: (352) 443-2412 | Office: (352) 372-3392

Scheduling: uesgainesville@universalengineering.com

