



---

**Britt Surveying and Mapping, LLC**  
2086 SW Main Blvd Ste 112 • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

11/17/20021

Permit # 000042058

L-28129


K & H Framing

Re: Lot 16 Forest Country 6<sup>th</sup> addition

To Whom It May Concern:

The top of the finished slab on said parcel is 109.76 feet. The required finished floor elevation is 109.0 feet per the building permit. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,

  
L. Scott Britt  
LS 5757