

Area Schedule (Life Safety) - Level1											
Level	Name	Occupant Loads Options	Occupant Load			Stair Load			Other Load		
			A + SFPP = OL			OL x SWR = SWR vs. SWP			OL x OF = OWR vs. OWP		
			Area	S.F. Per Person	Occupant Load	Stair Factor	Stair Width Required (Inches)	Stair Width Provided (Inches)	Other Factor	Other Width Required (Inches)	Other Width Provided (Inches)
LEVEL 1	ASSEMBLY	Assembly without fixed seats (unconcentrated tables and chairs) A-3	4387 SF	15	292	0	0		0.2	58	108
LEVEL 1	BUSINESS	Business areas (2018 IBC)	9412 SF	150	63	0	0		0.2	13	132
			13800 SF		355		0	0		71	240

NOTES

1. OCCUPANT LOAD FACTOR IS DETERMINED PER MOST STRINGENT REQUIREMENTS OF NFPA 101 TABLE 7.3.1.2 AND IBC TABLE 1004.1.2

2. EGRESS CAPACITY WIDTH FACTOR IS DETERMINED PER MOST STRINGENT REQUIREMENTS OF NFPA 101 TABLE 7.3.3, NFPA 101 TABLE 7.3.3.1 AND IBC SECTION 1005.

3. MINIMUM CLEAR EXIT EGRESS WIDTH REQUIRED IS 44 INCHES, PER MOST STRINGENT REQUIREMENTS OF NFPA 101 SECTION 7.3.2 AND IBC SECTION 1005

4. MAXIMUM TRAVEL DISTANCE FROM "THE MOST REMOTE POINT IN A ROOM" TO "AN EXIT" IS 300 FEET, PER MOST STRINGENT REQUIREMENTS OF NFPA 101 SECTION 7.6, IBC SECTION 1016 AND IBC TABLE 1016.2.

GENERAL NOTES FOR LIFE SAFETY PLANS

- G200. THE LIFE SAFETY PLANS ARE "DIAGRAMMATIC ONLY". THEIR PURPOSE IS SOLELY TO REPRESENT THE LIFE SAFETY COMPONENTS FOR THE PROJECT (AS INCLUDED IN THE CONSTRUCTION DOCUMENTS PREPARED BY THE ARCHITECT AND ENGINEERS). THE CONTRACTOR SHALL USE THE CONSTRUCTION DOCUMENTS (NOT THE LIFE SAFETY PLANS) FOR THE IMPLEMENTATION OF THE REQUIRED LIFE SAFETY COMPONENTS INTO THE PROJECT.
- G201. THE CONTRACTOR SHALL ADVISE THE ARCHITECT IMMEDIATELY UPON DISCOVERY OF ANY LIFE SAFETY COMPONENT THAT IS SHOWN ON THE LIFE SAFETY PLANS BUT HAS NOT BEEN INCLUDED IN THE CONSTRUCTION DOCUMENTS PREPARED BY THE ARCHITECT AND/OR ENGINEERS
- G202. THE CONTRACTOR SHALL BE RESPONSIBLE FOR FIELD VERIFYING THAT THE REQUIRED VISIBILITY FOR EACH EXIT SIGN SHALL BE VISIBLE, WITHOUT DIMINISHMENT IN THE DIRECTION OF TRAVEL.
- G203. THE CONTRACTOR SHALL BE RESPONSIBLE FOR STENCILING EACH "WALL/PARTITION/BARRIER" CLASSIFICATION IN RED LETTERS ABOVE THE FINISH CEILING ON EACH SIDE OF ALL PARTITIONS. PER THE REQUIREMENTS OF THE SPECIFICATIONS.

LEGEND

NON-RATED PARTITION	
ONE-HOUR FIRE BARRIER	
ONE-HOUR SMOKE BARRIER	
CLEAR WIDTH OF EGRESS DOOR (IN INCHES)	
TRAVEL DISTANCE TO EXIT DOOR	
EXIT LIGHTS (ARROWS INDICATE DIRECTION OF EGRESS)	
FIRE EXTINGUISHER/FIRE EXTINGUISHER CABINET	
STANDPIPE	



GreshamSmith.com

ARCHITECT, INTERIOR DESIGN, GRAPHICS
Gresham Smith
222 2nd Avenue South, Suite 1400
Nashville, TN 37201-2308
615.770.8100
FL Qualifier No. AR0013420
FL Registry No. RY3806
MEP Proj Mgr: Paul C. McKinney
Architect/Interior Designer of Record:
Eric M. Snyder
Florida Registration #96197
Project Principal: Rob Hamby
Project Architect: Eric Snyder
Project Coordinator: Traci Myers
Interior Designer: Morgan Black

ME&P
I.C. Thomasson Associates, Inc.
2950 Kraft Drive, Suite 500
Nashville, TN 37204
615.346.3400
FL Qualifier No. 38970
FL Registry No. 1276
MEP Principal: Josh Cartwright
MEP Proj Mgr: Paul C. McKinney
Mech Engineer of Record:
Shawn Sullivan
Florida Registration #81099
Plum/Fire P. Designer:
Donna Seigel
Elec. Engineer of Record:
Paul C. McKinney
Florida Registration #56569


STRUCTURAL
Stanley O. Lindsey & Associates, Ltd.
750 Old Hickory Blvd, Building 1, Suite 175
Brentwood, TN 37027
615.320.1735
FL Qualifier No. 39200
FL Registry No. 1329
Project Principal/ Engineer:
Mark Hiler
Structural Engineer of Record:
Michael E. Corrin
Florida Registration #62025

CIVIL & LANDSCAPE
Kimley-Horn
2615 Centennial Blvd., Suite 102
Tallahassee, FL 32308
850.553.3500
FL Qualifier No. ???
FL Registry No. 696
EOR: Kelsey Lewis, PE
Florida Registration #79384
Proj Mgr: Chris Akers
Landscape AOR: Charlie Johnson
Landscape Florida Reg #6667402



I.C. Thomasson Associates, Inc.

CONSULTING ENGINEERS
2950 KRAFT DRIVE, SUITE 500
NASHVILLE, TN. 37204
PHONE (615) 346-3400
FAX (615) 346-3550
www.ictthomasson.com



214 OceanSide Drive
Nashville, TN 37204



HCA Design & Construction
One Park Plaza, PO Box 550
Bldg. II, East 3rd Floor
Nashville, TN 37203
HCA Design Mgr.: Nicole Hoch
HCA Constr. Mgr.: Ben McAlpin

General Contractors
Robins & Morton
5500 Maryland Way, Suite 100
Brentwood, TN 37027



Reason: This item has been digitally signed and sealed by Eric Snyder on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.
Contact Info: 843-364-3494
Date: 2021.12.06 17:30:06-05'00'

ANCILLARY BUILDING

LAKE CITY MEDICAL CENTER

340 NW Commerce Dr.
Lake City, FL 32055

HCA Project No.: 3793800011

Revision		
No.	Date	Description

FIRST FLOOR - LIFE SAFETY PLAN

AL201C

LINE IS 3 INCHES WHEN PRINTED FULL SIZE
FULL SHEET SIZE = 36"x42"

PROJECT: 45057.00
DATE: 12/06/2021