

# Florida Building Code, Sixth Edition (2017) - Energy Conservation

EnergyGauge Summit® Fla/Com-2017, Effective Date: Dec 31, 2017

IECC 2015 - Total Building Performance Compliance Option

## Check List

Applications for compliance with the Florida Building Code, Energy Conservation shall include:



This Checklist



The full compliance report generated by the software that contains the project summary, compliance summary, certifications and detailed component compliance reports.



The compliance report must include the full input report generated by the software as contiguous part of the compliance report.



Boxes appropriately checked in the Mandatory Section of the compliance report.

## PROJECT SUMMARY

**Short Desc:** 1946

**Description:** NEW KITCHEN EXPANSION

**Owner:** TABERNACLE BAPTIST CHURCH

**Address1:** 144 SE Montrose Ave

**City:** Lake City

**Address2:**

**State:** FL

**Zip:** 32025

**Type:** Religious Building

**Class:** Addition to existing Building

**Jurisdiction:** LAKE CITY, COLUMBIA COUNTY, FL (221200)

**Conditioned Area:** 920 SF

**Conditioned & UnConditioned Area:** 920 SF

**No of Stories:** 1

**Area entered from Plans** 920 SF

**Permit No:** 0

**Max Tonnage** 4

**If different, write in:** \_\_\_\_\_

| <b>Compliance Summary</b>  |               |                 |                  |
|--|---------------|-----------------|------------------|
| <b>Component</b>   | <b>Design</b> | <b>Criteria</b> | <b>Result</b>    |
| Gross Energy Cost (in \$)  | 556.0         | 613.0           | <b>PASSED</b>    |
| LIGHTING CONTROLS  |               |                 | <b>PASSES</b>    |
| EXTERNAL LIGHTING  |               |                 | <b>No Entry</b>  |
| HVAC SYSTEM  |               |                 | <b>PASSES</b>    |
| PLANT  |               |                 | <b>No Entry</b>  |
| WATER HEATING SYSTEMS  |               |                 | <b>PASSES</b>    |
| PIPING SYSTEMS   |               |                 | <b>PASSES</b>    |
| Met all required compliance from Check List?   |               |                 | <b>Yes/No/NA</b> |
| <b>IMPORTANT MESSAGE</b><br>Info 5009 -- -- -- An input report of this design building must be submitted along with this Compliance Report |               |                 |                  |

## CERTIFICATIONS

I hereby certify that the plans and specifications covered by this calculation are in compliance with the Florida Energy Code

Prepared By: Richard E Coburn PE

Building Official: \_\_\_\_\_

**Richard E Coburn**  
Digitally signed by  
Richard E Coburn  
Date: 2020.11.09  
09:15:52 -05'00'

Date: \_\_\_\_\_

I certify that this building is in compliance with the FLorida Energy Efficiency Code

Owner Agent: \_\_\_\_\_

Date: \_\_\_\_\_

If Required by Florida law, I hereby certify (\*) that the system design is in compliance with the Florida Energy Efficiency Code

Architect: \_\_\_\_\_

Reg No: \_\_\_\_\_

Electrical Designer: Richard E Coburn PE

Reg No: E32820

Lighting Designer: Richard E Coburn PE

Reg No: E32820

Mechanical Designer: Richard E Coburn PE

Reg No: E32820

Plumbing Designer: Richard E Coburn PE

Reg No: E32820

(\*) Signature is required where Florida Law requires design to be performed by registered design professionals. Typed names and registration numbers may be used where all relevant information is contained on signed/sealed plans.

Project: 1946  
Title: NEW KITCHEN EXPANSION  
Type: Religious Building  
(WEA File: FL\_JACKSONVILLE\_INTL\_ARPT.tm3)

### Building End Uses

|                          | 1) Proposed  | 2) Baseline  |
|--------------------------|--------------|--------------|
| <b>Total</b>             | <b>35.60</b> | <b>46.30</b> |
|                          | <b>\$556</b> | <b>\$721</b> |
| ELECTRICITY(MBtu/kWh/\$) | 35.60        | 46.30        |
|                          | 10452        | 13584        |
|                          | <b>\$556</b> | <b>\$721</b> |
| AREA LIGHTS              | 7.00         | 11.60        |
|                          | 2058         | 3409         |
|                          | <b>\$109</b> | <b>\$181</b> |
| MISC EQUIPMT             | 13.80        | 13.80        |
|                          | 4044         | 4044         |
|                          | <b>\$215</b> | <b>\$215</b> |
| PUMPS & MISC             | 0.10         | 0.10         |
|                          | 36           | 40           |
|                          | <b>\$2</b>   | <b>\$2</b>   |
| SPACE COOL               | 7.90         | 6.40         |
|                          | 2303         | 1868         |
|                          | <b>\$123</b> | <b>\$99</b>  |
| SPACE HEAT               | 0.90         | 2.30         |
|                          | 271          | 671          |
|                          | <b>\$14</b>  | <b>\$36</b>  |
| VENT FANS                | 5.90         | 12.10        |
|                          | 1740         | 3552         |
|                          | <b>\$93</b>  | <b>\$189</b> |

Credits Applied: None

Passing Criteria = 613

Design (including any credits) = 556

Passing requires Proposed Building cost to be at most 85% of  
Baseline cost. This Proposed Building is at 77.1%

**PASSES**

| External Lighting Compliance |          |           |                       |   |             |            |
|------------------------------|----------|-----------|-----------------------|---|-------------|------------|
| Description                  | Category | Tradable? | Allowance<br>(W/Unit) | Area or Length<br>or No. of Units<br>(Sqft or ft) | ELPA<br>(W) | CLP<br>(W) |
|                              |          |           |                       |   |             | None       |

| <b>Project: 1946</b><br><b>Title: NEW KITCHEN EXPANSION</b><br><b>Type: Religious Building</b><br><b>(WEA File: FL_JACKSONVILLE_INTL_ARPT.tm3)</b> |           |                        |                 |           |        |            |
|--|-----------|------------------------|-----------------|-----------|--------|------------|
| Lighting Controls Compliance   |           |                        |                 |           |        |            |
| Acronym  | Ashrae ID | Description            | Area<br>(sq.ft) | Design CP | Min CP | Compliance |
| KITHCEN  | 7         | Food Service - Kitchen | 920             | 1         | 1      | PASSES     |
|  |           |                        |                 |           |        | PASSES     |

| <b>Project: 1946</b><br><b>Title: NEW KITCHEN EXPANSION</b><br><b>Type: Religious Building</b><br><b>(WEA File: FL_JACKSONVILLE_INTL_ARPT.tm3)</b> |   |  |            |              |             |               |                   |
|--|---|--|------------|--------------|-------------|---------------|-------------------|
| System Report Compliance   |   |  |            |              |             |               |                   |
| AC-3   | AC-3  | Constant Volume Air Cooled Split System < 65000 Btu/hr |            |              |             |               | No. of Units<br>1 |
| Component  | Category  | Capacity   | Design Eff | Eff Criteria | Design IPLV | IPLV Criteria | Compliance        |
| Cooling System   | Air Conditioners Air Cooled Split System < 65000 Btu/h Cooling Capacity | 48000  | 13.00      | 13.00        | 12.00       |               | PASSES            |
| Heating System   | Electric Furnace  | 24000  | 1.00       | 1.00         |             |               | PASSES            |
| Air Handling System -Supply  | Air Handler (Supply) - Constant Volume                                  | 1600   | 0.50       | 0.82         |             |               | PASSES            |
|  |   |  |            |              |             |               | PASSES            |

| Plant Compliance |              |      |            |         |             |          |          |            |
|------------------|--------------|------|------------|---------|-------------|----------|----------|------------|
| Description      | Installed No | Size | Design Eff | Min Eff | Design IPLV | Min IPLV | Category | Compliance |
|                  |              |      |            |         |             |          |          | None       |

| <b>Project: 1946</b><br><b>Title: NEW KITCHEN EXPANSION</b><br><b>Type: Religious Building</b><br><b>(WEA File: FL_JACKSONVILLE_INTL_ARPT.tm3)</b> |                       |            |            |         |             |          |            |        |
|--|-----------------------|------------|------------|---------|-------------|----------|------------|--------|
| Water Heater Compliance  |                       |            |            |         |             |          |            |        |
| Description  | Type                  | Category   | Design Eff | Min Eff | Design Loss | Max Loss | Compliance |        |
| Water Heater 1   | Electric water heater | <= 12 [kW] | 98.00      | 0.94    |             |          | PASSES     |        |
|  |                       |            |            |         |             |          |            | PASSES |

| <b>Project: 1946</b><br><b>Title: NEW KITCHEN EXPANSION</b><br><b>Type: Religious Building</b><br><b>(WEA File: FL_JACKSONVILLE_INTL_ARPT.tm3)</b> |                   |            |                    |                            |                |                    |            |        |
|--|-------------------|------------|--------------------|----------------------------|----------------|--------------------|------------|--------|
| Piping System Compliance   |                   |            |                    |                            |                |                    |            |        |
| Category   | Pipe Dia [inches] | Is Runout? | Operating Temp [F] | Ins Cond [Btu-in/hr .SF.F] | Ins Thick [in] | Req Ins Thick [in] | Compliance |        |
| Domestic and Service Hot Water Systems   | 1.50              | False      | 120.00             | 0.28                       | 1.00           | 1.00               | PASSES     |        |
|  |                   |            |                    |                            |                |                    |            | PASSES |

## Mandatory Requirements (as applicable)

Mandatory requirements compiled by US Department of Energy and Pacific Northwest National Laboratory. Adopted with permission

| Topic   | Section                                    | Component         | Description   | Yes                                 | N/A                                 | Exempt                   |
|---|--|-------------------|---|-------------------------------------|-------------------------------------|--------------------------|
| <b>1. To be checked by Designer or Engineer</b> |  |                   |   |                                     |                                     |                          |
| Insulation                                      | C303.2                                     | Envelope          | Below-grade wall insulation installed per manufacturer's instructions.  | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Insulation                                      | C303.2                                     | Envelope          | Slab edge insulation installed per manufacturer's instructions.   | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Insulation                                      | C303.2                                     | Envelope          | Above-grade wall insulation installed per manufacturer's instructions.  | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/> |
| Insulation                                      | C402.3                                     | Envelope          | High-albedo roofs satisfy one of the following: 3-year-aged solar reflectance $\geq 0.55$ and thermal emittance $\geq 0.75$ or 3-year-aged solar reflectance index $\geq 64.0$ .  | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Fenestration                                    | C402.4.4                                   | Envelope          | U-factor of opaque doors associated with the building thermal envelope meets requirements.  | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/> |
| SYSTEM_SPECIFIC                                 | C403.2.12.1                                | Mechanical        | HVAC fan systems at design conditions do not exceed allowable fan system motor nameplate hp or fan system bhp.  | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/> |
| SYSTEM_SPECIFIC                                 | C403.2.12.2                                | Mechanical        | HVAC fan motors not oversized beyond allowable limits.  | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/> |
| SYSTEM_SPECIFIC                                 | C403.2.3(8) Table                          | Mechanical        | Heat Rejection Equipment: Minimum Efficiency Requirement meet those listed in Table C403.2.3(8)   | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/> |
| HVAC  | C403.2.7                                   | Mechanical        | Exhaust air energy recovery on systems meeting Table C403.2.7(1) and C403.2.7(2).   | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC                                 | C403.3                                     | Mechanical        | Air economizers provided where required, meet the requirements for design capacity, control signal, ventilation controls, high-limit shut-off, integrated economizer control, and provide a means to relieve excess outside air during operation. | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC                                 | C403.3.2                                   | Mechanical        | Economizer operation will not increase heating energy use during normal operation.  | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC                                 | C403.3.4, C403.3.4.1, C403.3.4.2, C403.3.1 | Mechanical        | Water economizers provided where required, meet the requirements for design capacity, maximum pressure drop and integrated economizer control.  | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC                                 | C403.4.2.1                                 | Mechanical        | Three-pipe hydronic systems using a common return for hot and chilled water are not used.   | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC                                 | C403.4.2.3.1                               | Mechanical        | Hydronic heat pump systems connected to a common water loop meet heat rejection and heat addition requirements.   | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC                                 | C403.4.3.4                                 | Mechanical        | Open-circuit cooling towers having water cooled chiller systems and multiple or variable speed condenser pumps, are designed so that tower cells can run in parallel with larger of flow criteria.  | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC                                 | C404.2                                     | Mechanical        | Service water heating equipment meets efficiency requirements.  | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/> |
| Wattage   | C405.3                                     | Interior Lighting | Exit signs do not exceed 5 watts per face.  | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/> |
| <b>2. To be checked by Plan Reviewer</b>        |  |                   |   |                                     |                                     |                          |
| Plan Review                                     | C103.2                                     | Envelope          | Plans and/or specifications provide all information with which compliance can be determined for the building envelope and document where exceptions to the standard are claimed.  | <input type="checkbox"/>            | <input type="checkbox"/>            | <input type="checkbox"/> |



|                 |             |                   |   |                          |                          |                          |
|-----------------|-------------|-------------------|---|--------------------------|--------------------------|--------------------------|
| Plan Review     | C103.2      | Mechanical        | Plans, specifications, and/or calculations provide all information with which compliance can be determined for the mechanical systems and equipment and document where exceptions to the standard are claimed. Load calculations per acceptable engineering st  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Plan Review     | C103.2      | Mechanical        | Plans, specifications, and/or calculations provide all information with which compliance can be determined for the service water heating systems and equipment and document where exceptions to the standard are claimed. Hot water system sized per manufact   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Plan Review     | C103.2      | Interior Lighting | Plans, specifications, and/or calculations provide all information with which compliance can be determined for the interior lighting and electrical systems and equipment and document where exceptions to the standard are claimed. Information provided shoul | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Plan Review     | C103.2      | Exterior Lighting | Plans, specifications, and/or calculations provide all information with which compliance can be determined for the exterior lighting and electrical systems and equipment and document where exceptions to the standard are claimed. Information provided shoul | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Insulation      | C402.2.5    | Envelope          | Slab edge insulation depth/length. Slab insulation extending away from building is covered by pavement or $\geq 10$ inches of soil.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Insulation      | C402.2.6    | Project           | Radiant heating systems panels insulated to $\geq R-3.5$ on face opposite space being heated.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| HVAC            | C402.2.6    | Mechanical        | Thermally ineffective panel surfaces of sensible heating panels have insulation $\geq R-3.5$ .  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Insulation      | C402.2.6    | Envelope          | Radiant panels and associated components, designed for heat transfer from the panel surfaces to the occupants or indoor space are insulated with a minimum of R-3.5.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Air Leakage     | C402.5.7    | Envelope          | Vestibules are installed on all building entrances. Doors have self-closing devices.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.2.12.3 | Mechanical        | Fans have efficiency grade (FEG) $\geq 67$ . The total efficiency of the fan at the design point of operation $\leq 15\%$ of maximum total efficiency of the fan.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| HVAC            | C403.2.13   | Mechanical        | Unenclosed spaces that are heated use only radiant heat.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| HVAC            | C403.2.4.2  | Mechanical        | Each zone equipped with setback controls using automatic time clock or programmable control system.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.2.4.4  | Mechanical        | Zone isolation devices and controls installed where applicable.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.2.4.7  | Mechanical        | Fault detection and diagnostics installed with air-cooled unitary DX units having economizers.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.2.5    | Mechanical        | Hot water boilers supplying heat via one- or two-pipe systems include outdoor setback control.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| HVAC            | C403.2.6.1  | Mechanical        | Demand control ventilation provided for spaces $>500$ ft <sup>2</sup> and $>25$ people/1000 ft <sup>2</sup> occupant density and served by systems with air side economizer, auto modulating outside air damper control, or design airflow $>3,000$ cfm.        | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.4.1.1  | Mechanical        | Hydronic and multizone HVAC system controls are VAV fans driven by mechanical or electrical variable speed drive per Table C403.4.1.1.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.4.1.3  | Mechanical        | Reset static pressure setpoint for DDC controlled VAV boxes reporting to central controller based on the zones requiring the most pressure.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.4.2    | Mechanical        | Temperature reset by representative building loads in pumping systems for chiller and boiler systems $>500,000$ Btu/h.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

|                 |                               |                   |   |                          |                          |                          |
|-----------------|-------------------------------|-------------------|---|--------------------------|--------------------------|--------------------------|
| SYSTEM_SPECIFIC | C403.4.2.3.2.1                | Mechanical        | Closed-circuit cooling tower within heat pump loop have either automatic bypass valve or lower leakage positive closure dampers. Open-circuit tower within heat pump loop have automatic valve to bypass all heat pump water flow around the tower. Open- or cl         | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.4.2.4                    | Mechanical        | Hydronic systems greater than 500,000 Btu/h designed for variable fluid flow.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.4.2.5                    | Mechanical        | System turndown requirement met through multiple single-input boilers, one or more modulating boilers, or a combination of single-input and modulating boilers. Boiler input between 1.0 MBtu/h and 5 MBtu/h has 3:1 turndown ratio, boiler input between 5.0           | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.4.2.6                    | Mechanical        | Chilled water plants with multiple chillers have capability to reduce flow automatically through the chiller plant when a chiller is shut down. Boiler plants with multiple boilers have the capability to reduce flow automatically through the boiler plant           | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.4.3,<br>C403.4.3.2       | Mechanical        | Fan systems with motors $\geq 7.5$ hp associated with heat rejection equipment to have capability to operate at 2/3 of full-speed and auto speed controls to control the leaving fluid temperature or condensing temp/pressure of heat rejection device.                | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.4.4.5                    | Mechanical        | Multiple zone HVAC systems have supply air temperature reset controls.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.4.4.6                    | Mechanical        | Multiple zone VAV systems with DDC of individual zone boxes have static pressure setpoint reset controls.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C404.2.1                      | Mechanical        | Gas-fired water-heating equipment installed in new buildings: where a singular piece of water-heating equipment $\geq 1,000$ kBtu/h serves the entire building, thermal efficiency $\geq 90$ Et. Where multiple pieces of water-heating equipment serve the building wi | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C404.4                        | Mechanical        | All piping insulated in accordance with section details and Table C403.2.10.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C404.5, C404.5.1,<br>C404.5.2 | Mechanical        | Heated water supply piping conforms to pipe length and volume requirements. Refer to section details.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C404.6.3                      | Mechanical        | Pumps that circulate water between a heater and storage tank have controls that limit operation from startup to $\leq 5$ minutes after end of heating cycle.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C404.7                        | Mechanical        | Water distribution system that pumps water from a heated-water supply pipe back to the heated-water source through a cold-water supply pipe is a demand recirculation water system. Pumps within this system have controls that start the pump upon receiving           | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Wattage         | C405.5.1                      | Exterior Lighting | Exterior lighting power is consistent with what is shown on the approved lighting plans, demonstrating proposed watts are less than or equal to allowed watts.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Plan Review     | C405.6                        | Project           | Group R-2 dwelling units have separate electrical meters.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Plan Review     | C406                          | Project           | Plans, specifications, and/or calculations provide all information with which compliance can be determined for the additional energy efficiency package options.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C408.2.2.2                    | Mechanical        | HVAC hydronic heating and cooling coils have means to balance and have pressure test connections.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C408.2.2.2                    | Mechanical        | HVAC hydronic heating and cooling coils have means to balance and have pressure test connections.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

### 3. To be checked by Inspector

|              |                      |          |   |                          |                          |                          |
|--------------|----------------------|----------|---|--------------------------|--------------------------|--------------------------|
| Insulation   | C303.1               | Envelope | Roof insulation installed per manufacturer's™ instructions. Blown or poured loose-fill insulation is installed only where the roof slope is ≤3 in 12.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Insulation   | C303.1               | Envelope | Building envelope insulation is labeled with R-value or insulation certificate providing R-value and other relevant data.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Fenestration | C303.1.3             | Envelope | Fenestration products rated in accordance with NFRC.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Fenestration | C303.1.3             | Envelope | Fenestration products are certified as to performance labels or certificates provided.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Insulation   | C303.2, C402.2.4     | Envelope | Floor insulation installed per manufacturer's instructions. Cavity or structural slab insulation installed in permanent contact with underside of decking or structural slabs.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Insulation   | C303.2.1             | Envelope | Exterior insulation protected against damage, sunlight, moisture, wind, landscaping and equipment maintenance activities.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Insulation   | C303.2.1             | Envelope | Exterior insulation is protected from damage with a protective material. Verification for exposed foundation insulation may need to occur during Foundation Inspection.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Insulation   | C402.1.3             | Envelope | Non-swinging opaque doors have R-4.75 insulation.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Insulation   | C402.2.2             | Envelope | Skylight curbs are insulated to the level of roofs with insulation above deck or R-5.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Insulation   | C402.2.2             | Envelope | Insulation intended to meet the roof insulation requirements cannot be installed on top of a suspended ceiling. Mark this requirement compliant if insulation is installed accordingly.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Air Leakage  | C402.5               | Envelope | Building envelope contains a continuous air barrier that has been tested and deemed to limit air leakage ≤ 0.40 cfm/ft2.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Air Leakage  | C402.5.1             | Envelope | The building envelope contains a continuous air barrier that is sealed in an approved manner and either constructed or tested in an approved manner. Air barrier penetrations are sealed in an approved manner.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Air Leakage  | C402.5.1.1           | Envelope | All sources of air leakage in the building thermal envelope are sealed, caulked, gasketed, weather stripped or wrapped with moisture vapor-permeable wrapping material to minimize air leakage.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Air Leakage  | C402.5.1.2.1         | Envelope | The building envelope contains a continuous air barrier that is sealed in an approved manner and material permeability ≤ 0.004 cfm/ft2. Air barrier penetrations are sealed in an approved manner.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Air Leakage  | C402.5.1.2.2         | Envelope | The building envelope contains a continuous air barrier that is sealed in an approved manner and average assembly air leakage ≤ 0.04 cfm/ft2. Air barrier penetrations are sealed in an approved manner.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Air Leakage  | C402.5.2, C402.5.4   | Envelope | Factory-built fenestration and doors are labeled as meeting air leakage requirements.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Air Leakage  | C402.5.3             | Envelope | Where open combustion air ducts provide combustion air to open combustion fuel burning appliances, the appliances and combustion air opening are located outside the building thermal envelope or enclosed in a room, isolated from inside the thermal envelope | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Air Leakage  | C402.5.5, C403.2.4.3 | Envelope | Stair and elevator shaft vents have motorized dampers that automatically close.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Air Leakage  | C402.5.5, C403.2.4.3 | Envelope | Outdoor air and exhaust systems have motorized dampers that automatically shut when not in use and meet maximum leakage rates. Check gravity dampers where allowed.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Air Leakage  | C402.5.6             | Envelope | Weatherseals installed on all loading dock cargo doors.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

|                 |                            |            |   |                          |                          |                          |
|-----------------|----------------------------|------------|---|--------------------------|--------------------------|--------------------------|
| Air Leakage     | C402.5.8                   | Envelope   | Recessed luminaires in thermal envelope to limit infiltration and be IC rated and labeled. Seal between interior finish and luminaire housing.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| HVAC            | C403.2.1                   | Mechanical | HVAC systems and equipment design loads calculated in accordance with ANSI/ASHRAE/ACCA Standard 183 or by an approved equivalent computational procedure  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.2.10                  | Mechanical | HVAC piping insulation thickness. Where piping is installed in or under a slab, verification may need to occur during Foundation Inspection.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| HVAC            | C403.2.3                   | Mechanical | HVAC equipment efficiency verified.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.2.3                   | Mechanical | PTAC and PTHP with sleeves 16 in. by 42 in. labeled for replacement only as per Footnote b to Table C403.2.3(3).  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.2.4.1                 | Mechanical | Heating and cooling to each zone is controlled by a thermostat control. Minimum one humidity control device per installed humidification/dehumidification system.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.2.4.1.1               | Mechanical | Heat pump controls prevent supplemental electric resistance heat from coming on when not needed.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| HVAC            | C403.2.4.1.2               | Mechanical | Thermostatic controls have a 5 Â°F deadband.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| HVAC            | C403.2.4.1.2               | Mechanical | Thermostatic controls have a 5 Â°F deadband.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| HVAC            | C403.2.4.1.3               | Mechanical | Temperature controls have setpoint overlap restrictions.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| HVAC            | C403.2.4.2.1, C403.2.4.2.2 | Mechanical | Automatic Controls: Setback to 55°F (heat) and 85°F (cool); 7-day clock, 2-hour occupant override, 10-hour backup   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.2.4.2.3               | Mechanical | Systems include optimum start controls.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| HVAC            | C403.2.4.5, C403.2.4.6     | Mechanical | Snow/ice melting system sensors for future connection to controls. Freeze protection systems have automatic controls installed.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| HVAC            | C403.2.6.2                 | Mechanical | Enclosed parking garage ventilation has automatic contaminant detection and capacity to stage or modulate fans to 50% or less of design capacity.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| HVAC            | C403.2.9                   | Mechanical | HVAC ducts and plenums insulated. Where ducts or plenums are installed in or under a slab, verification may need to occur during Foundation Inspection.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.2.9.1.3               | Mechanical | Ductwork operating >3 in. water column requires air leakage testing.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.4.1.2                 | Mechanical | VAV fans have static pressure sensors located so controller setpoint <=1.2 w.c..  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.4.2.2                 | Mechanical | Two-pipe hydronic systems using a common distribution system have controls to allow a deadband >=15°F, allow operation in one mode for at least 4 hrs before changeover, and have rest controls to limit heating and cooling supply temperature to <=30 °F. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.4.2.3.3               | Mechanical | Two-position automatic valve interlocked to shut off water flow when hydronic heat pump with pumping system >10 hp is off.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.4.4.5, C403.4.4.5.1-4 | Mechanical | Zone controls can limit simultaneous heating and cooling and sequence heating and cooling to each zone.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.4.5                   | Mechanical | Condenser heat recovery system that can heat water to 85°F or provide 60% of peak heat rejection is installed for preheating of service hot water.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C403.4.6                   | Mechanical | Hot gas bypass limited to:<br><=240 kBtu/h - 50% capacity,<br>>240 kBtu/h - 25% capacity  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC | C404.3                     | Mechanical | Heat traps installed on non-circulating storage water tanks.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

|                          |                                  |                   |  |                          |                          |                          |
|--------------------------|----------------------------------|-------------------|--|--------------------------|--------------------------|--------------------------|
| SYSTEM_SPECIFIC          | C404.3                           | Mechanical        | Heat traps installed on supply and discharge piping of non-circulating systems.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC          | C404.3                           | Mechanical        | Heat traps installed on supply and discharge piping of non-circulating systems.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC          | C404.6.1                         | Mechanical        | Controls are installed that limit the operation of a recirculation pump installed to maintain temperature of a storage tank. System return pipe is a dedicated return pipe or a cold water supply pipe.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC          | C404.6.1, C404.6.2               | Mechanical        | Automatic time switches installed to automatically switch off the recirculating hot-water system or heat trace.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC          | C404.9.1                         | Mechanical        | Pool heaters are equipped with on/off switch and no continuously burning pilot light.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC          | C404.9.2                         | Mechanical        | Time switches are installed on all pool heaters and pumps.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC          | C404.9.2                         | Mechanical        | Time switches are installed on all pool heaters and pumps.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| SYSTEM_SPECIFIC          | C404.9.3                         | Mechanical        | Vapor retardant pool covers are provided for heated pools and permanently installed spas.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Controls                 | C405.2.1                         | Interior Lighting | Lighting controls installed to uniformly reduce the lighting load by at least 50%.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Controls                 | C405.2.1                         | Interior Lighting | Occupancy sensors installed in required spaces.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Controls                 | C405.2.1, C405.2.2.3             | Interior Lighting | Independent lighting controls installed per approved lighting plans and all manual controls readily accessible and visible to occupants.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Controls                 | C405.2.2.1                       | Interior Lighting | Automatic controls to shut off all building lighting installed in all buildings.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Controls                 | C405.2.3                         | Interior Lighting | Daylight zones provided with individual controls that control the lights independent of general area lighting.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Controls                 | C405.2.3, C405.2.3.1, C405.2.3.2 | Interior Lighting | Primary sidelighted areas are equipped with required lighting controls.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Controls                 | C405.2.3, C405.2.3.1, C405.2.3.3 | Interior Lighting | Enclosed spaces with daylight area under skylights and rooftop monitors are equipped with required lighting controls.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Controls                 | C405.2.4                         | Interior Lighting | Separate lighting control devices for specific uses installed per approved lighting plans.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Wattage                  | C405.2.4                         | Interior Lighting | Additional interior lighting power allowed for special functions per the approved lighting plans and is automatically controlled and separated from general lighting.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Controls                 | C405.2.5                         | Exterior Lighting | Automatic lighting controls for exterior lighting installed. Controls will be daylight controlled, set based on business operation time-of-day, or reduce connected lighting > 30%.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Wattage                  | C405.4.1                         | Interior Lighting | Interior installed lamp and fixture lighting power is consistent with what is shown on the approved lighting plans, demonstrating proposed watts are less than or equal to allowed watts.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Mandatory Additional Eff | C406.4                           | Project           | Enhanced digital lighting controls efficiency package: Interior lighting has following enhanced lighting controls in accordance with Section C405.2.2:<br>Luminaires capable of continuous dimming and being addressed individually, <= 8 luminaires controlled in | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Mandatory Additional Eff | C406.6                           | Project           | Dedicate outdoor air system efficiency package : Buildings with hydronic and/or multiple-zone HVAC systems are equipped with an independent ventilation system designed to provide >= 100-percent outdoor air to each individual occupied space, as specified by   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

|  |                    |                   |   |                          |                          |                          |
|--|--------------------|-------------------|---|--------------------------|--------------------------|--------------------------|
| Mandatory Additional Eff   | C406.7, C406.7.1   | Project           | Enhanced Service Water Heat System efficiency package. One of the following SWH system enhancements must satisfy 60 percent of hot water requirements, or 100 percent if the building otherwise complies with heat recovery per Section C403.4.5: Waste heat re | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| HVAC   | C408.2.2.1         | Mechanical        | Air outlets and zone terminal devices have means for air balancing.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| HVAC   | C408.2.2.1         | Mechanical        | Air outlets and zone terminal devices have means for air balancing.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Testing  | C408.2.3.2         | Mechanical        | HVAC control systems have been tested to ensure proper operation, calibration and adjustment of controls.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <b>4. To be checked by Inspector at Project Completion and Prior to Issuance of Certificate of Occupancy</b> |                    |                   |   |                          |                          |                          |
| Post Construction  | C303.3, C408.2.5.2 | Interior Lighting | Furnished O&M instructions for systems and equipment to the building owner or designated representative.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Post Construction  | C303.3, C408.2.5.3 | Mechanical        | Furnished O&M manuals for HVAC systems within 90 days of system acceptance.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Fenestration   | C402.4.2.2         | Envelope          | Skylights in office, storage, automotive service, manufacturing, non-refrigerated warehouse, retail store, and distribution/sorting area have a measured haze value > 90 percent unless designed to exclude direct sunlight.                                    | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Post Construction  | C408.2.1           | Mechanical        | Commissioning plan developed by registered design professional or approved agency.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Post Construction  | C408.2.3.1         | Mechanical        | HVAC equipment has been tested to ensure proper operation.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Post Construction  | C408.2.3.3         | Mechanical        | Economizers have been tested to ensure proper operation.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Post Construction  | C408.2.4           | Mechanical        | Preliminary commissioning report completed and certified by registered design professional or approved agency.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Post Construction  | C408.2.5.1         | Mechanical        | Furnished HVAC as-built drawings submitted within 90 days of system acceptance.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Post Construction  | C408.2.5.1         | Interior Lighting | Furnished as-built drawings for electric power systems within 90 days of system acceptance.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Post Construction  | C408.2.5.3         | Mechanical        | An air and/or hydronic system balancing report is provided for HVAC systems.  | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Post Construction  | C408.2.5.4         | Mechanical        | Final commissioning report due to building owner within 90 days of receipt of certificate of occupancy.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Post Construction  | C408.3             | Interior Lighting | Lighting systems have been tested to ensure proper calibration, adjustment, programming, and operation.   | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

# Input Data Report

## Project Information

**Project Name:** 1946

**Project Title:** NEW KITCHEN EXPANSION

**Address:** 144 SE Montrose Ave

**State:** FL

**Zip:** 32025

**Owner:** TABERNACLE BAPTIST CHURC

**Building Type:** Religious Building

**Building Classification:** Addition to existing Building

**No.of Stories:** 1

**GrossArea (SF):** 920

**Bldg. Rotation:** None

### Zones

| No | Acronym | Description | Type        | Area<br>[sf] | Multi | Total Area<br>[sf] |                          |
|----|---------|-------------|-------------|--------------|-------|--------------------|--------------------------|
| 1  | AC-3    | AC-3        | CONDITIONED | 920.0        | 1     | 920.0              | <input type="checkbox"/> |

### Spaces

| No                   | Acronym | Description | Type                   | Depth<br>[ft] | Width<br>[ft] | Height<br>[ft] | Mult | Total<br>Area<br>[sf] | Total<br>Vol[cf] |                          |
|----------------------|---------|-------------|------------------------|---------------|---------------|----------------|------|-----------------------|------------------|--------------------------|
| <b>In Zone:</b> AC-3 |         |             |                        |               |               |                |      |                       |                  |                          |
| 1                    | KITHCEN | KITHCEN     | Food Service - Kitchen | 1.00          | 920.00        | 14.00          | 1    | 920.0                 | 12880.0          | <input type="checkbox"/> |

### Lighting

| No                       | Type | Category         | No. of<br>Luminaires | Watts per<br>Luminaire | Power<br>[W] | Control Type  | No.of<br>Ctrl pts |                          |
|--------------------------|------|------------------|----------------------|------------------------|--------------|---------------|-------------------|--------------------------|
| <b>In Zone:</b> AC-3     |      |                  |                      |                        |              |               |                   |                          |
| <b>In Space:</b> KITHCEN |      |                  |                      |                        |              |               |                   |                          |
| 1                        | LED  | General Lighting | 12                   | 56                     | 672          | Manual On/Off | 1                 | <input type="checkbox"/> |

### Walls (Walls will be rotated clockwise by building rotation value)

| No                   | Description | Type  | Width<br>[ft] | H (Effec)<br>[ft] | Multi<br>plier | Area<br>[sf] | Orient<br>ation | Cond-<br>uctance<br>[Btu/h.sf.F] | Heat<br>Capacity<br>[Btu/sf.F] | Dens.<br>[lb/cf] | R-Value<br>[h.sf.F/Btu] |                          |
|----------------------|-------------|---|---------------|-------------------|----------------|--------------|-----------------|----------------------------------|--------------------------------|------------------|-------------------------|--------------------------|
| <b>In Zone: AC-3</b> |             |   |               |                   |                |              |                 |                                  |                                |                  |                         |                          |
| 1                    | NORTH       | Metal<br>siding/2x4@24"+R1<br>1Batt/5/8"Gyp | 32.00         | 12.00             | 1              | 384.0        | North           | 0.0920                           | 1.072                          | 19.38            | 10.9                    | <input type="checkbox"/> |
| 2                    | SOUTH       | Metal<br>siding/2x4@24"+R1<br>1Batt/5/8"Gyp | 32.00         | 12.00             | 1              | 384.0        | South           | 0.0920                           | 1.072                          | 19.38            | 10.9                    | <input type="checkbox"/> |
| 3                    | EAST        | Metal<br>siding/2x4@24"+R1<br>1Batt/5/8"Gyp | 32.00         | 14.00             | 1              | 448.0        | East            | 0.0920                           | 1.072                          | 19.38            | 10.9                    | <input type="checkbox"/> |

### Windows (Windows will be rotated clockwise by building rotation value)

| No                    | Description | Orientation | Shaded | U<br>[Btu/hr sf F] | SHGC | Vis.Tra | W<br>[ft] | H (Effec)<br>[ft] | Multi<br>plier | Total Area<br>[sf] |                          |
|-----------------------|-------------|-------------|--------|--------------------|------|---------|-----------|-------------------|----------------|--------------------|--------------------------|
| <b>In Zone: AC-3</b>  |             |             |        |                    |      |         |           |                   |                |                    |                          |
| <b>In Wall: NORTH</b> |             |             |        |                    |      |         |           |                   |                |                    |                          |
| 1                     | WINDOW      | North       | No     | 1.2500             | 0.82 | 0.76    | 4.00      | 6.00              | 1              | 24.0               | <input type="checkbox"/> |
| <b>In Wall: SOUTH</b> |             |             |        |                    |      |         |           |                   |                |                    |                          |
| 1                     | WINDOW      | South       | No     | 1.2500             | 0.82 | 0.76    | 4.00      | 6.00              | 1              | 24.0               | <input type="checkbox"/> |

### Doors

| No | Description | Type | Shade? | Width<br>[ft] | H (Effec)<br>[ft] | Multi<br>plier | Area<br>[sf] | Cond.<br>[Btu/h.sf.F] | Dens.<br>[lb/cf] | Ht Cap.<br>[Btu/sf.<br>F] | R<br>[h.sf.F/<br>Btu] |
|----|-------------|------|--------|---------------|-------------------|----------------|--------------|-----------------------|------------------|---------------------------|-----------------------|
|----|-------------|------|--------|---------------|-------------------|----------------|--------------|-----------------------|------------------|---------------------------|-----------------------|

**In Zone:**

**In Wall:**

☐



## Roofs

| No | Description | Type | Width<br>[ft] | H (Effec)<br>[ft] | Multi<br>plier | Area<br>[sf] | Tilt<br>[deg] | Cond.<br>[Btu/h.Sf. F] | Heat Cap<br>[Btu/sf. F] | Dens.<br>[lb/cf] | R-Value<br>[h.sf.F/Btu] |
|----|-------------|------|---------------|-------------------|----------------|--------------|---------------|------------------------|-------------------------|------------------|-------------------------|
|----|-------------|------|---------------|-------------------|----------------|--------------|---------------|------------------------|-------------------------|------------------|-------------------------|

In Zone: AC-3

|   |      |                         |        |      |   |       |      |        |      |      |      |                          |
|---|------|-------------------------|--------|------|---|-------|------|--------|------|------|------|--------------------------|
| 1 | ROOF | Mtl Bldg Roof/R-30 Batt | 920.00 | 1.00 | 1 | 920.0 | 0.00 | 0.0330 | 1.62 | 8.28 | 30.3 | <input type="checkbox"/> |
|---|------|-------------------------|--------|------|---|-------|------|--------|------|------|------|--------------------------|

## Skylights

| No | Description | Type | U<br>[Btu/hr sf F] | SHGC | Vis.Trans | W<br>[ft] | H (Effec)<br>[ft] | Multi-<br>plier | Area<br>[Sf] | Total Area<br>[Sf] |
|----|-------------|------|--------------------|------|-----------|-----------|-------------------|-----------------|--------------|--------------------|
|----|-------------|------|--------------------|------|-----------|-----------|-------------------|-----------------|--------------|--------------------|

In Zone:

In Roof:

☐

## Floors

| No | Description | Type | Width<br>[ft] | H (Effec)<br>[ft] | Multi<br>plier | Area<br>[sf] | Cond.<br>[Btu/h.sf.F] | Heat Cap.<br>[Btu/sf. F] | Dens.<br>[lb/cf] | R-Value<br>[h.sf.F/Btu] |
|----|-------------|------|---------------|-------------------|----------------|--------------|-----------------------|--------------------------|------------------|-------------------------|
|----|-------------|------|---------------|-------------------|----------------|--------------|-----------------------|--------------------------|------------------|-------------------------|

In Zone: AC-3

|   |       |   |        |      |   |       |        |       |        |      |                          |
|---|-------|---|--------|------|---|-------|--------|-------|--------|------|--------------------------|
| 1 | FLOOR | 1 ft. soil, concrete floor, carpet and rubber pad | 920.00 | 1.00 | 1 | 920.0 | 0.2681 | 34.00 | 113.33 | 3.73 | <input type="checkbox"/> |
|---|-------|---|--------|------|---|-------|--------|-------|--------|------|--------------------------|

## Systems

| AC-3      |                             | AC-3     |  |            | Constant Volume Air Cooled<br>Split System < 65000 Btu/hr |  | No. Of Units             |  |
|-----------|-----------------------------|----------|--|------------|---|--|--------------------------|--|
|           |                             |          |  |            |   |  | 1                        |  |
| Component | Category                    | Capacity |  | Efficiency | IPLV  |  |                          |  |
| 1         | Cooling System              | 48000.00 |  | 13.00      | 12.00   |  | <input type="checkbox"/> |  |
| 2         | Heating System              | 24000.00 |  | 1.00       |   |  | <input type="checkbox"/> |  |
| 3         | Air Handling System -Supply | 1600.00  |  | 0.50       |   |  | <input type="checkbox"/> |  |

## Plant

| Equipment | Category | Size | Inst.NoEff. | IPLV |
|-----------|----------|------|-------------|------|
|-----------|----------|------|-------------|------|

## Water Heaters

| W-Heater Description |                       | Capacity | Cap.Unit | I/P Rt. | Efficiency   | Loss                             |
|----------------------|-----------------------|----------|----------|---------|--------------|----------------------------------|
| 1                    | Electric water heater | 20 [Gal] |          | 3 [kW]  | 98.0000 [Ef] | [Btu/h] <input type="checkbox"/> |

## Ext-Lighting

| Description | Category | No. of<br>Lumin-<br>aires | Watts per<br>Lumin-<br>aire | Area/Len/No<br>[sf/ft/No] | Control<br>Type | Wattage<br>[W] |
|-------------|----------|---------------------------|-----------------------------|---------------------------|-----------------|----------------|
|             |          |                           |                             |                           |                 |                |
|             |          |                           |                             |                           |                 |                |

## Piping

| No | Type                                   | Operating Temp<br>[F] | Insulation Conductivity<br>[ Btu-in/h.sf.F] | Nominal pipe Diameter<br>[in] | Insulation Thickness<br>[in] | Is Runout?                  |
|----|--|-----------------------|---|-------------------------------|------------------------------|-----------------------------|
| 1  | Domestic and Service Hot Water Systems | 120.00                | 0.28  | 1.50                          | 1.00                         | No <input type="checkbox"/> |

## Fenestration Used

| Name               | Glass Type   | No. of Panes | Glass Conductance<br>[Btu/h.sf.F] | SHGC   | VLT    |
|--------------------|--------------|--------------|-----------------------------------|--------|--------|
| ASHULSglClrAll Frn | User Defined | 1            | 1.2500                            | 0.8200 | 0.7600 |

## Materials Used

| Mat No | Acronym | Description                | Only R-Value Used | RValue [h.sf.F/Btu] | Thick [ft] | Conductivity [Btu/h.ft.F] | Density [lb/cf] | Sp. Heat [Btu/lb.F] |                          |
|--------|---------|----------------------------|-------------------|---------------------|------------|---------------------------|-----------------|---------------------|--------------------------|
| 187    | Matl187 | GYP OR PLAS BOARD,1/2IN    | No                | 0.4533              | 0.0417     | 0.0920                    | 50.00           | 0.2000              | <input type="checkbox"/> |
| 178    | Matl178 | CARPET W/RUBBER PAD        | Yes               | 1.2300              |            |                           |                 |                     | <input type="checkbox"/> |
| 265    | Matl265 | Soil, 1 ft                 | No                | 2.0000              | 1.0000     | 0.5000                    | 100.00          | 0.2000              | <input type="checkbox"/> |
| 48     | Matl48  | 6 in. Heavyweight concrete | No                | 0.5000              | 0.5000     | 1.0000                    | 140.00          | 0.2000              | <input type="checkbox"/> |
| 23     | Matl23  | 6 in. Insulation           | No                | 20.0000             | 0.5000     | 0.0250                    | 5.70            | 0.2000              | <input type="checkbox"/> |
| 4      | Matl4   | Steel siding               | No                | 0.0002              | 0.0050     | 26.0000                   | 480.00          | 0.1000              | <input type="checkbox"/> |
| 271    | Matl271 | 2x4@24" oc + R11 Batt      | No                | 10.4179             | 0.2917     | 0.0280                    | 7.11            | 0.2000              | <input type="checkbox"/> |
| 94     | Matl94  | BUILT-UP ROOFING, 3/8IN    | No                | 0.3366              | 0.0313     | 0.0930                    | 70.00           | 0.3500              | <input type="checkbox"/> |

## Constructs Used

| No   | Name  | Simple Construct | Massless Construct         | Conductance [Btu/h.sf.F] | Heat Cap [Btu/sf.F] | Density [lb/cf] | RValue [h.sf.F/Btu] |                          |
|------|---|------------------|----------------------------|--------------------------|---------------------|-----------------|---------------------|--------------------------|
| 1055 | Metal siding/2x4@24"+R11Batt/5/8"Gyp              | No               | No                         | 0.09                     | 1.07                | 19.38           | 10.9                | <input type="checkbox"/> |
|      | Layer   | Material No.     | Material                   | Thickness [ft]           |                     | Framing Factor  |                     |                          |
|      | 1   | 4                | Steel siding               | 0.0050                   |                     | 0.000           |                     | <input type="checkbox"/> |
|      | 2   | 271              | 2x4@24" oc + R11 Batt      | 0.2917                   |                     | 0.000           |                     | <input type="checkbox"/> |
|      | 3   | 187              | GYP OR PLAS BOARD,1/2IN    | 0.0417                   |                     | 0.000           |                     | <input type="checkbox"/> |
| No   | Name  | Simple Construct | Massless Construct         | Conductance [Btu/h.sf.F] | Heat Cap [Btu/sf.F] | Density [lb/cf] | RValue [h.sf.F/Btu] |                          |
| 1056 | Mtl Bldg Roof/R-30 Batt                           | No               | No                         | 0.03                     | 1.62                | 8.28            | 30.3                | <input type="checkbox"/> |
|      | Layer   | Material No.     | Material                   | Thickness [ft]           |                     | Framing Factor  |                     |                          |
|      | 1   | 94               | BUILT-UP ROOFING, 3/8IN    | 0.0313                   |                     | 0.000           |                     | <input type="checkbox"/> |
|      | 2   | 23               | 6 in. Insulation           | 0.7500                   |                     | 0.000           |                     | <input type="checkbox"/> |
| No   | Name  | Simple Construct | Massless Construct         | Conductance [Btu/h.sf.F] | Heat Cap [Btu/sf.F] | Density [lb/cf] | RValue [h.sf.F/Btu] |                          |
| 1057 | 1 ft. soil, concrete floor, carpet and rubber pad | No               | No                         | 0.27                     | 34.00               | 113.33          | 3.7                 | <input type="checkbox"/> |
|      | Layer   | Material No.     | Material                   | Thickness [ft]           |                     | Framing Factor  |                     |                          |
|      | 1   | 265              | Soil, 1 ft                 | 1.0000                   |                     | 0.000           |                     | <input type="checkbox"/> |
|      | 2   | 48               | 6 in. Heavyweight concrete | 0.5000                   |                     | 0.000           |                     | <input type="checkbox"/> |
|      | 3   | 178              | CARPET W/RUBBER PAD        |                          |                     | 0.000           |                     | <input type="checkbox"/> |