

**A&B Well Drilling, Inc.**

5673 NW Lake Jeffery Road  
Lake City, FL 32055  
Telephone: (386) 758-3408  
Cell: (386) 628-3154  
Fax: (386) 758-3410  
Owner: Bruce Park

October 31 2013

To: Columbia County Building Department

Description of Well to be installed for Customer: Columbia County Station 50

Located @ Address: NW Marshon St \_\_\_\_\_

1.5 HP 20 GPM submersible pump, 1 1/2" drop pipe, 86 gallon captive tank, and backflow prevention.  
With SRWMD permit.



Sincerely,  
Bruce N. Park  
President



## COLUMBIA COUNTY FIRE / RESCUE

P.O. BOX 1529 Lake City, Florida 32056  
Office (386) 754-7071 Fax (386) 754-7064

Fire Chief  
David L. Boozer

04 November 2013

TO: Columbia County Building Department

FROM: David L. Boozer  
Fire Chief

RE: Applications 1310-57/58/59

A plans review was performed of the proposed construction of the Columbia County Fire Rescue Departments #49, 50, and 51. This building meets the requirements as outlined in the 2010 Florida Fire Prevention Code.  
I recommend approval.

Sincerely,

David L. Boozer