

Permit # 42440

# Addendum to Wind Load Requirements

**206 SE Sandia Way, Lake City, Columbia County, Florida**  
**(In Compliance with the 2020 Florida Building Code)**

Prepared By: Marty J. Humphries, P.E. # 51976  
7932 240th St., O'Brien, FL 32071  
(386)362-9169

The following requirement are in addition to, and supercedes (where applicable) the wind load requirements dated 6-22-21 for the above mentioned residence.

- 1.) Two Simpson H2.5 anchors may be used in place of the single H10A hurricane clip for truss connections.
- 2.) During construction the anchor bolts were place 4' on center along the sole plate instead of the called for 3' spacing in the windload. Install one Simpson 5/8" x 6" Titen heavy duty masonry screw (THDB62600H)(no washers required) between the existing anchor bolts to provide additional uplift and shear capacity.



THIS DOCUMENT HAS BEEN DIGITALLY SIGNED AND SEALED BY:

**Marty J  
Humphries**

Digitally signed by  
Marty J Humphries  
Date: 2022.04.08  
13:23:07 -04'00'

PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED  
SIGNED AND SEALED. THE SIGNATURE MUST BE VERIFIED ON  
THE ELECTRONIC DOCUMENTS.