

Roof Replacement or Repair Application #72395

Tuesday, July 29, 2025 9:55 AM



Checklist:

___ Address	___ Application Submitted	
___ Drive/ROW	___ Zoning Review	___ Legal Lot of Record
___ Septic	___ Plans Reviewed	___ Flood Zone
___ Site Use Approved	___ Required Inspections Assigned	___ FDEP Needed
___ Docs Reviewed/Accepted	___ Invoiced	

APPLICANT: Tanesha Bouthner

PHONE: (813) 695-9203

ADDRESS: 1130 1st Street South Winter Haven FL 33880

OWNER: GRANTHAM MICHAEL WAYNE, GRANTHAM SANDRA GAYLE

PHONE: (315) 217-1968

ADDRESS: 364 SW RIDGE ST LAKE CITY, FL 32024

PARCEL ID: 25-4S-16-03155-121

SUBDIVISION: OAK RIDGE ESTATES UNIT III

LOT: 21 **BLOCK:** **PHASE:** **UNIT:** **ACRES:** 4.29

CONTRACTOR	TYPE	LIC#	BUSINESS NAME
Tanesha Bouthner	General	CCC1335469	Solar Roofing & Construction Specialist Corp

ROOFING JOB DETAILS

Type Roofing Job	Replacement - Tear off Existing and Replace
Further Job Details (Explain if decking is being replaced and or Repairs are being done.)	Shingle to Shingle
Type of structure	House
Further Structure Details (if needed)	Single family residence and two out buildings at same address
Total Estimated Cost	44600.00
Commercial or Residential	Residential
Roof Area (for this job) Sq Ft	8723
No. of Stories	1
Ventilation:	Ridge Vent
Flashing:	Replace All
Drip Edge:	Replace All
Valley Treatment:	New Metal
Roof Pitch	4:12 or Greater
Second Roof Pitch (if applicable)	4:12 or Greater
Any cable and/or race-way wiring located on or within the roof assembly?	No
Is the existing roof being removed?	Yes
Explain if not removing the existing roofing material?	
Type of New Roofing Product	Asphalt Shingles
Florida Product Approval Number	FL18355-R12
Product Manufacturer	Tamko
Product Description	Ashalt Shingle
Other Roofing Product Type Not Listed	

Sealed roof decking options: (Must select an option.)

a minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 ¼ - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire roof.

Sealed roof decking explanation for other option.

Review Notes: