

Work Order

| | | | |
|-----------|-----------------------------------------------------|-----------------|------------------------------------------|
| Number | 2025-00002563 | Request Date | 2/24/2025 12:00:00 AM |
| Type | IR New Tap | Schedule Date | 2/24/2025 12:00:00 AM |
| Priority | | Assign Date | |
| Requester | Amy Fernandez | Assigned To | Brown, Stephen E |
| Account | 079540-002 WITTENBORN, REBECCA Phone: 2292699475 | Service Address | 172 NW MALLARD PL LAKE CITY, FL 32055 |

| | |
|----------|--------------------------------|
| Comments | 140. New Tap - Turn on gas. AF |
|----------|--------------------------------|

| New Meter Device | | | | |
|------------------|--|--|--|--|
| | | | | |
| | | | | |
| | | | | |
| | | | | |

5min manom press held @8 w/c cgi test generator & conn. cgi
test good

| | | | |
|------|-------------|------|---------|
| Read | <u>0435</u> | Read | <u></u> |
| | <u></u> | | <u></u> |
| | <u></u> | | <u></u> |
| | <u></u> | | <u></u> |

| | | | |
|-----------|----------------|-----------|-----------------------------------|
| Read Date | <u>2-24-25</u> | Read Date | <u> </u> / <u> </u> / <u> </u> |
|-----------|----------------|-----------|-----------------------------------|

| | |
|----------|---------|
| Comments | <u></u> |
| | <u></u> |

| | |
|---------------|------------------|
| Completed By: | <u>DJK JRR</u> |
| | <u>2:32-2:43</u> |