



Project Summary
Entire House
Glenn I. Jones, Inc.

Job:
Date: Aug 12, 2012
By:

552 NW Hilton Ave, Lake City, FL 32055 Phone: 386-752-5389 Fax: 386-755-3401 Email: byron@gijinc.com Web: www.glennijonesinc.com

Project Information

For: Steven Hice
258 SE Willow Dr, Lake City, FL 32025
Phone: 386-719-8907

Notes:

Design Information

Weather: Gainesville, FL, US

Winter Design Conditions

Outside db	33 °F
Inside db	70 °F
Design TD	37 °F

Summer Design Conditions

Outside db	92 °F
Inside db	75 °F
Design TD	17 °F
Daily range	M
Relative humidity	50 %
Moisture difference	52 gr/lb

Heating Summary

Structure	35165 Btuh
Ducts	13399 Btuh
Central vent (0 cfm)	0 Btuh
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	48564 Btuh

Sensible Cooling Equipment Load Sizing

Structure	33160 Btuh
Ducts	16495 Btuh
Central vent (0 cfm)	0 Btuh
Blower	0 Btuh
Use manufacturer's data	n
Rate/swing multiplier	0.97
Equipment sensible load	48165 Btuh

Infiltration

Method	Simplified
Construction quality	Average
Fireplaces	0

Latent Cooling Equipment Load Sizing

Structure	4112 Btuh
Ducts	3894 Btuh
Central vent (0 cfm)	0 Btuh
Equipment latent load	8006 Btuh
Equipment total load	56171 Btuh
Req. total capacity at 0.84 SHR	4.8 ton

	Heating	Cooling
Area (ft ²)	2679	2679
Volume (ft ³)	26790	26790
Air changes/hour	0.32	0.16
Equiv. AVF (cfm)	143	71

Heating Equipment Summary

Make Carrier
Trade Comfort 15
Model 25HBC560
AHRI ref no3646391

Efficiency	8.7 HSPF
Heating input	
Heating output	57000 Btuh @ 47°F
Temperature rise	25 °F
Actual air flow	2044 cfm
Air flow factor	0.042 cfm/Btuh
Static pressure	0 in H2O
Space thermostat	

Cooling Equipment Summary

Make Carrier	
Trade Comfort 15	
Cond 25HBC560	
Coil FX4DNF061T00	
AHRI ref no3646391	
Efficiency	15 SEER
Sensible cooling	47880 Btuh
Latent cooling	9120 Btuh
Total cooling	57000 Btuh
Actual air flow	2044 cfm
Air flow factor	0.041 cfm/Btuh
Static pressure	0 in H2O
Load sensible heat ratio	0.86

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2012 12.0.04 RSU01086
R:\Wrightsoft HVAC\Project\hice steven.rup Calc = MJ8 Front Door faces: N

2012-Aug-24 10:11:42

Page 1



This combination qualifies for a Federal Energy Efficiency Tax Credit when placed in service between Feb 17, 2009 and Dec 31, 2011.

Certificate of Product Ratings

AHRI Certified Reference Number: 3646391

Date: 8/24/2012

Product: Split System: Heat Pump with Remote Outdoor Unit-Air-Source

Outdoor Unit Model Number: 25HBC560A**30

Indoor Unit Model Number: FX4DN(B,F)061

Manufacturer: CARRIER AIR CONDITIONING

Trade/Brand name: BASE 15 PURON HP

Manufacturer responsible for the rating of this system combination is CARRIER AIR CONDITIONING

Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (Btuh):	57000
EER Rating (Cooling):	12.50
SEER Rating (Cooling):	15.00
Heating Capacity(Btuh) @ 47 F:	57000
Region IV HSPF Rating (Heating):	8.70
Heating Capacity(Btuh) @ 17 F:	35400

* Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed below.



Air-Conditioning, Heating, and Refrigeration Institute

©2012 Air-Conditioning, Heating, and Refrigeration Institute

CERTIFICATE NO.: 129902897936529741

31
GLENN I. JONES INC.

COOLING • HEATING

SPECIALISTS

State Cert. # CAC051486

552 N.W. Hilton Ave. Lake City, FL 32055
386-752-5389 fax 386-755-3401

gij@bellsouth.net

08/12/2012

Reference:HVAC permit:

Hice Residence

Material proposal

Mastic

Foil tape

Insulation wrap

Pvc drain piping

Equipment:

Carrier 25HBC560, FX4DNF061T00, CE0901N10, TC-NHP01

Installing the Best • Servicing the Rest