

## FIELD DENSITY WORKSHEET

CLIENT Amira Builders DATE 2-2-22  
 PROJECT NO. \_\_\_\_\_  
 PROJECT NAME 100 SW Sugar Bear Glen (Ft White) PERMIT NO. \_\_\_\_\_  
 EARTH CONTRACTOR \_\_\_\_\_ TESTED BY KW  
 COMPACTION REQUIREMENT (%) 95 ☐ Standard Proctor ☐ Modified Proctor FIELD CONTACT \_\_\_\_\_  
 TOTAL ON-SITE TIME \_\_\_\_\_ MILES FROM OFFICE \_\_\_\_\_  
☐ Limerock ☐ Subgrade ☐ Pipe Backfill ☐ Building Pad ☐ Building Footing ☐ Other \_\_\_\_\_

TEST LOCATION	LAB PROCTOR		TEST DEPTH	PROBE DEPTH	% MOIST.	WET DENSITY (PCF)	DRY DENSITY (PCF)	% COMP.
	DENS.	OMC						
app 6' NW of SE corner	107.6	10.0	F/G	12"	6.9	111.9	104.7	97.3
app center of pad.	↓	↓	↓	↓	6.4	110.4	103.7	96.4
app 5' SE of NW corner	↓	↓	↓	↓	6.7	111.7	104.7	97.3

REMARKS \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

- \* Density failed to meet minimum project requirement
- \*\* Retest indicates minimum density requirement was obtained.
- ( ) Client is aware of unsatisfactory test results.