



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

08/29/2022

Permit # 000044718

L-28931

Cheryl Newmann

Re: 04096-013

To Whom It May Concern:

The finished floor elevation of the residence is found to be 63.13 feet. The Engineer's letter shows the minimum floor elevation to be 63.9 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,



L. Scott Britt
LS 5757