



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

9/29/2020

Permit # 000039673

Lot 16 of Cannon Creek Place

L-26977

Mike Roberts

To whom it may concern,
The elevation of the top of the slab on Lot 16 is found to be 95.20 feet. The minimum floor elevation is shown to 94.58 feet per the permit. The Elevations shown hereon are based on NAVD 88 Datum.

Sincerely,


L. Scott Britt
LS 5757