



---

**Britt Surveying and Mapping, LLC**  
2086 SW Main Blvd Ste 112 • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

9/29/2020

Permit # 000040036

Lot 93 of Emerald Cove Phase 1

L-26964

Cornerstone Development

To whom it may concern,

The elevation of the top of the slab on Lot 93 is found to be 112.05 feet. The minimum floor elevation is shown to be 111.00 feet per the permit. Elevations are shown in NAVD 88 Datum.

Sincerely,

A handwritten signature in black ink, appearing to read "L. Scott Britt", is written over a faint, circular, textured background.

L. Scott Britt  
LS 5757