



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

01/29/18

L-25026


Re: Lot 11 Amelia Landings Phase 1

Adam's Construction

To Whom It May Concern:

The top of the foundation elevation is found to be 116.67 feet on said lot 11. The lowest adjacent grade is found to be 115.9 feet, and the highest adjacent grade is found to be 116.1 feet. The minimum floor elevation per the plat of record is 116.50 feet. The elevations shown hereon are based on plat datum.

Sincerely,


L. Scott Britt
LS 5757

35998