



Britt Surveying and Mapping, LLC

1438 SW Main Blvd • Lake City, FL 32025

386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

10/23/2022

Permit # 000045106

L-29044


Re: Lot 32 Forest Country 5th Addition

Castagna Construction

To Whom It May Concern:

The finished floor elevation for the slab on said Lot 32 is found to be 104.97 feet. The minimum floor elevation per the building permit is shown to be 104.7 feet. All elevations are shown in NAVD 88 datum.

Sincerely,



L. Scott Britt

LS 5757