



17 OCTOBER 2025

BUILDING OFFICIAL
LAKE CITY BUILDING DEPT.
CITY HALL, LAKE CITY, FLORIDA
LAKE CITY, FLORIDA 32055

RE: WALL DAMAGE REPAIR @ 287 SW STARLIGHT COURT, LAKE CITY, FLORIDA
PERMIT Nr.: _____

DEAR SIR:

PLEASE BE ADVISED OF THE FOLLOWING REQUIRE REPAIRS TO THE DAMAGED GARAGE WALL FOR THE ABOVE REFERENCED PROJECT:

1. EXISTING CRACKED STUDS SHALL BE PULLED BACK INTO TRUE VERTICAL ALIGNMENT PRIOR TO PLACING SISTER STUDS.
2. SISTER STUDS SHALL BE PLACED ADJACENT TO DAMAGED STUDS AND SECURED THERETO WITH 10d RING SHANK NAILS AT 6" O.C. - ADDED STUDS SHALL EXTEND FROM THE SILL PLATE TO THE UNDERSIDE OF THE DOUBLE WALLPLATE ABOVE.
3. SECURE NEW SISTER STUDS TO THE EXISTING WALL PLATES WITH "SIMPSON" RSP4 ANCHOR CLIPS.
4. RESTORE INTERIOR AND EXTERIOR WALL FINISHES TO MATCH REMAINING EXISTING FINISHES AND REPLACE THE EXISTING DAMAGED WINDOW.

SHOULD YOU HAVE ANY FURTHER QUESTIONS WITH THIS, PLEASE CALL FOR ASSISTANCE.

YOURS TRULY,
NICHOLAS PAUL GEISLER, ARCHITECT

