

#53184

ROOFING UNDERLAYMENT AFFIDAVIT

Columbia County, Florida Building Department

135 NE Hernando Avenue Lake City, Florida 32055 Phone: 386-758-1008

www.columbiacountyfla.com

REQUIRED FOR WALK-IN OR PAPER SUBMITTALS
Job Address: 732 NW Emerald Lakes Drive
I (<u>Print Name</u>) <u>BARRY Joye</u> , as a Florida license Roofing Contractor or an Owner Builder, I understand to comply with the 2020 Florida Building Code 7 th Edition underlayment requirements, I must select an option for sealing the roof deck.
The options are summarized below
a self-adhering polymer-modified bitumen underlayment complying with ASTM D1970 applied over the entire roof.
a minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire roof.
two layers of felt underlayment comply ASTM 0226 Type II or ASTM D4869 Type III or IV, or two layers of a synthetic underlayment meeting the performance requirements specified, lapped and fastened as specified.
Other (explain)
Contractor/Owners Signature

FINAL INSPECTION & CERTIFICATE OF COMPLETION:

This completed form and photographs must be uploaded to your permit via online at the Application Submission login (link) Welcome to Columbia County Online (columbia countyfla.com).

Clearly visible in the Photographs must be the permit number or address and must include a ruler or measuring device to confirm nail spacing and overlaps including drip edge and valley flashing.

53184



Columbia County, Florida Building Department

135 NE Hernando Avenue Lake City, Florida 32055

Phone: 386-758-1008

ROOFING AFFIDAVIT

www.columbiacountyfla.com

JOB ADDRESS: 732 NW Emerald Lakes Drive
I (Print Name) Barry Joy Contractor, licensed under Chapter 468, Florida Statutes as a(n): (Check One) Contractor Engineer Architect License Number: 468, Florida Statutes as a(n):
On this (Date) $\frac{1/31/22}{}$, did personally examine the roof at the above address for regulatory
compliance as required for: (Check all that apply)
Roof Deck Attachment Secondary Water Barrier Roof to Wall Connection
Attic Venting has been maintained and complies with Florida Building Code R-806.
Based on my examination, I have determined and affirm the installation is in accordance with the Florida Building Code 2020 7 th Edition and 2020 Florida Statute (553.844). (Affiant Signature)
STATE OF Florida
COUNTY Columbia
The foregoing instrument acknowledged before me by means of physical presence or online notarization, this day of february 2000, by BARRY Joye, who is personally known to me or has provided the following identification. Notary Public Signature (Seal) Notary Printed Name JERAIdINE HRUDA MY COMMISSION # GG 338932 EXPIRES: May 27, 2023 Bonded Thru Notary Public Underwriters

FINAL INSPECTION & CERTIFICATE OF COMPLETION:

This completed form and photographs must be uploaded to your permit via online at the Application Submission login (link) Welcome to Columbia County Online (columbiacountyfla.com).

Clearly visible in the Photographs must be the permit number or address, must include a ruler or measuring device to confirm nail spacing and overlaps including drip edge, valley flashing and attic venting.