



36704
Daniel & Gore, LLC

Professional Surveying and Mapping

P.O. Box 1501
Lake City, Florida 32056



August 15, 2018

David Simque
Lake City, FL 32025

Subject: Belmont Academy Robotics Building Elevation Letter

Dear David:

Daniel & Gore, LLC has performed a vertical survey on the Belmont Academy Robotics Building located on Parcel #11-5S-16-03568-004 of Columbia County, Florida from a benchmark being the finished floor of the existing school building (elevation – 72.61', per Donald Lee & Associates Elevation letter dated 10/24/12, datum unknown) and have determined the following:

- The Construction plans requires the minimum finish floor elevation to be 63.75'.
- The finished floor elevation of the Robotics Building is at 64.33', being 0.58' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,

Scott Daniel, PSM

Scott Daniel, PSM • Cell: (386) 208-4176 • E-mail: sdaniel@dgsurveying.com

David Gore • Cell: (386) 365-0298 • E-mail: dgore@dgsurveying.com

Fax: (904) 339-9229