



STATE OF FLORIDA
DEPARTMENT OF HEALTH
ONSITE SEWAGE TREATMENT AND DISPOSAL SYSTEM
CONSTRUCTION INSPECTION AND FINAL APPROVAL

APPLICATION #: AP1969033

PERMIT #: 12-SC-2712964

DOCUMENT #: F12053724

DATE PAID: 05/31/2023

FEE PAID: 310.00

RECEIPT #: 12-PID-6167255

APPLICANT: Scott**23-0403 Gove

AGENT: ROBERT FORD III (NORTH FL SEPTIC TANK INC)

PROPERTY ADDRESS: 10191 SE County Road 245 Lake City, FL 32024

LOT:

BLOCK:

SUBDIVISION:

ID#: 09227-007

CHECKED [X] ITEMS ARE NOT IN COMPLIANCE WITH STATUTE OR RULE AND MUST BE CORRECTED.

TANK INSTALLATION

[] [01] TANK SIZE [1] 1350.00 [2] 500.00
[] [02] TANK MATERIAL Concrete
[] [03] OUTLET DEVICE 700-Filter
[] [04] MULTI-CHAMBERED [] Y / N]
[] [05] OUTLET FILTER Tuf-Tite EF-4
[] [06] LEGEND 1. 34-107-13DC3 2. 34-107-05SC3
[] [07] WATERTIGHT
[] [08] LEVEL
[] [09] DEPTH TO LID

DRAINFIELD INSTALLATION

[] [10] AREA [1] 570 [2] SQFT
[] [11] DISTRIBUTION BOX HEADER X
[] [12] NUMBER OF DRAINLINES 1. 4.00 2.
[] [13] DRAINLINE SEPARATION
[] [14] DRAINLINE SLOPE
[] [15] DEPTH OF COVER
[] [16] ELEVATION [] ABOVE / BELOW] BM 48.00
[] [17] SYSTEM LOCATION
[] [18] DOSING PUMPS 1/3 Liberty
[] [19] AGGREGATE SIZE
[] [20] AGGREGATE EXCESSIVE FINES nil
[] [21] AGGREGATE DEPTH

FILL / EXCAVATION MATERIAL

[] [22] FILL AMOUNT
[] [23] FILL TEXTURE
[] [24] EXCAVATION DEPTH
[] [25] AREA REPLACED
[] [26] REPLACEMENT MATERIAL

SETBACKS

[] [27] SURFACE WATER nil FT
[] [28] DITCHES nil FT
[] [29] PRIVATE WELLS 400 FT
[] [30] PUBLIC WELLS nil FT
[] [31] IRRIGATION WELLS nil FT
[] [32] POTABLE WATER 10 5KV FT
[] [33] BUILDING FOUNDATIONS 5KV FT
[] [34] PROPERTY LINES 60 FT
[] [35] OTHER nil FT

FILLED / MOUND SYSTEM

[] [36] DRAINFIELD COVER
[] [37] SHOULDERS
[] [38] SLOPES
[] [39] STABILIZATION

ADDITIONAL INFORMATION

[] [40] UNOBSTRUCTED AREA
[] [41] STORMWATER RUNOFF
[] [42] ALARMS Rhembus
[] [43] MAINTENANCE AGREEMENT Ma
[] [44] BUILDING AREA
[] [45] LOCATION CONFORMS WITH SITE PLAN
[] [46] FINAL SITE GRADING
[] [47] CONTRACTOR Robert W Ford (North Florida
[] [48] OTHER INFILTRATOR ARC 24

ABANDONMENT

[] [49] TANK PUMPED
[] [50] TANK CRUSHED & FILLED

Comments:

CONSTRUCTION [] APPROVED / DISAPPROVED 1: Cassandra Bonds Columbia CHD DATE: 06/30/2023
Environmental Specialist | Cassandra Bonds (FDOH in Columbia Count)
FINAL SYSTEM [] APPROVED / DISAPPROVED 1: Cassandra Bonds Columbia CHD DATE: 7/7/23

(Explanation of Violations on following page)

DH 4016, 08/09 (Obsoletes all previous editions which may not be used)
Incorporated: 64E-6.003, FAC