

STATE OF FLORIDA
 DEPARTMENT OF HEALTH
 APPLICATION FOR ONSITE SEWAGE DISPOSAL SYSTEM CONSTRUCTION PERMIT

Permit Application Number 16-0444M

BURASS


PART II - SITEPLAN

210'

DRIVE/BURASS

Scale: 1 inch = 40 feet.

210'



Notes: ⓐ = PROPOSED ⓑ = EXISTING
1 OF 14.35 ACRES SEE ATTACHED

Site Plan submitted by: [Signature] MASTER CONTRACTOR
 Plan Approved [Signature] Not Approved _____ Date 4/26/16
 By [Signature] Columbia County Health Department

ALL CHANGES MUST BE APPROVED BY THE COUNTY HEALTH DEPARTMENT



STATE OF FLORIDA
DEPARTMENT OF HEALTH
ONSITE SEWAGE TREATMENT AND DISPOSAL
SYSTEM
APPLICATION FOR CONSTRUCTION PERMIT

PERMIT NO. 16-0744M
DATE PAID: 4/17/16
FEE PAID: 125.00
RECEIPT #: 124186

APPLICATION FOR:

- New System Existing System Holding Tank Innovative
- Repair Abandonment Temporary ADDITIONAL

APPLICANT: Frank Burress

AGENT: ROCKY FORD, A & B CONSTRUCTION

TELEPHONE: 386-497-2311

MAILING ADDRESS: 546 SW Dortch Street, FT. WHITE, FL, 32038

TO BE COMPLETED BY APPLICANT OR APPLICANT'S AUTHORIZED AGENT. SYSTEMS MUST BE CONSTRUCTED BY A PERSON LICENSED PURSUANT TO 489.105(3)(m) OR 489.552, FLORIDA STATUTES. IT IS THE APPLICANT'S RESPONSIBILITY TO PROVIDE DOCUMENTATION OF THE DATE THE LOT WAS CREATED OR PLATTED (MM/DD/YY) IF REQUESTING CONSIDERATION OF STATUTORY GRANDFATHER PROVISIONS.

PROPERTY INFORMATION

LOT: na BLOCK: na SUB: na PLATTED: _____

PROPERTY ID #: 20-58-17-09301-003 ZONING: Ag I/M OR EQUIVALENT: [Y / N]

PROPERTY SIZE: 14.33 ACRES WATER SUPPLY: PRIVATE PUBLIC [] <=2000GED [] >2000GED

IS SEWER AVAILABLE AS PER 381.0065, FS? [Y / N] DISTANCE TO SEWER: _____ FT

PROPERTY ADDRESS: 250 SW Burress Glen, Lake City, FL, 32024

DIRECTIONS TO PROPERTY: Tustenuggee South, At south end of Oaks S/D, TL on Burress Glen, Follow drive to first house on right

BUILDING INFORMATION:


RESIDENTIAL [] COMMERCIAL

Unit No	Type of Establishment	No. of Bedrooms	Building Area Sqft	Commercial/Institutional System Design Table 1, Chapter 64E-6, FAC
1	SF Residential	4	1820	
2				
3				

Floor/Equipment Drains Other (Specify) _____

SIGNATURE: _____

DATE: 4/8/2016



STATE OF FLORIDA DEPARTMENT OF HEALTH ONSITE SEWAGE TREATMENT AND DISPOSAL SYSTEM CONSTRUCTION PERMIT

PERMIT #: 12-SC-1674191 APPLICATION #: AP1234186 DATE PAID: FEE PAID: RECEIPT #: DOCUMENT #: PR1015637

CONSTRUCTION PERMIT FOR: OSTDS Existing Modification APPLICANT: FRANK**16-0244 BURRESS PROPERTY ADDRESS: 250 SW BURRESS Gln Lake City, FL 32024 LOT: BLOCK SUBDIVISION. PROPERTY ID #: 09301-003

SYSTEM MUST BE CONSTRUCTED IN ACCORDANCE WITH SPECIFICATIONS AND STANDARDS OF SECTION 381.0065, F.S., AND CHAPTER 64E-6, F.A.C. DEPARTMENT APPROVAL OF SYSTEM DOES NOT GUARANTEE SATISFACTORY PERFORMANCE FOR ANY SPECIFIC PERIOD OF TIME.

SYSTEM DESIGN AND SPECIFICATIONS

T [900] GALLONS / GPD Existing Septic Tank CAPACITY A [] GALLONS / GPD N/A CAPACITY N [] GALLONS GREASE INTERCEPTOR CAPACITY [MAXIMUM CAPACITY SINGLE TANK 1250 GALLONS] K [] GALLONS DOSING TANK CAPACITY [] GALLONS [] DOSES PER 24 HRS #Pumps []

D [500] SQUARE FEET Drainfield SYSTEM R [] SQUARE FEET N/A SYSTEM A TYPE SYSTEM: [x] STANDARD [] FILLED [] MOUND [] I CONFIGURATION. [x] TRENCH [] BED []

F LOCATION OF BENCHMARK: Top of septic system, outlet end.

I ELEVATION OF PROPOSED SYSTEM SITE [1 00] [INCHES] FT [] ABOVE [] BELOW BENCHMARK/REFERENCE POINT E BOTTOM OF DRAINFIELD TO BE [21 00] [INCHES] FT [] ABOVE [] BELOW BENCHMARK/REFERENCE POINT

D FILL REQUIRED: [0.00] INCHES EXCAVATION REQUIRED: [0.00] INCHES

- 1) The system is sized for 4 bedrooms with a maximum occupancy of 8 persons (2 per bedroom), for a total estimated flow of 400 gpd. 2.) Modification permit. Do not disturb existing drainfield, instead add 250 SQFT of drainfield to existing 250 SQFT to achieve required area of 500 SQFT 3.) Outlet filter device must remain in place. If it has been removed, one must be installed at inspection

SPECIFICATIONS BY: ROCKY FORD TITLE: Master Contractor

APPROVED BY: [Signature] TITLE: Environmental Specialist I Columbia CHD

DATE ISSUED: 04/26/2016 EXPIRATION DATE: 10/26/2017

DN 4016, 08/09 (Obsoletes all previous editions which may not be used) Incorporated: 64E-6.003, FAC