NIVI5

MEMORANDUM

To:

All Concerned Parties

Date:

January 29, 2025

From:

Austin Blazs

Project:

24-0379.01

Subject:

Finished Floor Elevation letter for Lot 1, Preserve at

Laural Lake, Unit 1

Please accept this memorandum as my certification that the elevation of the lowest finished floor of the new residence constructed on Lot 1, Preserve at Laural Lake, Unit 1, as per plat recorded in Plat Book 9, Pages 19-25, was field measured on January 29, 2025, to be 116.12 feet. Said residence is in compliance with the Zoning setback requirements. The benchmark used as a basis for this measurement is based on NGS Data Point BD1031, with a designation of I75 71 A14.

The minimum finished floor elevation required for Lot 1, per an Elevation Letter provided by Christopher A. Potts, P.E. with LJA Engineering, is 115.80 feet.

Austin Blazs

Digitally signed by Austin Blazs DN: CN=Austin Blazs, O=Austin Blazs, L=Hawthorne, S=Florida,

Date: 2025.01.30 10:28:05-05'00'

Austin Blazs, PSM

Registered Florida Surveyor and Mapper Certificate Number 7401

Dermit # 000051632