



January 14, 2021

John Schildknecht
358 Cracknel Way
Lake City, FL 32055

SUBJECT: ELEVATION LETTER
Parcel No. 28-2S-16-01772-135
358 N.W. Cracknel Way, Lake City, Florida 32055

To Whom It May Concern:


Parcel No. 28-2S-16-01772-135 is located in Flood Zone X. The property naturally slopes north toward a low area south of NW Sugarcane Place. The manufactured home will be elevated on concrete blocks above a concrete slab when constructed. The minimum distance between the finished floor elevation and surrounding natural ground will be approximately twelve (12) inches. Stormwater will flow around the structure to the north.

Requirements for Structure to Be Protected from the Base Flood Event:

The Minimum Floor Elevation shall be at 98.0 feet NAVD and which will be a minimum of 12" above the highest adjacent natural grade at the proposed building site. Any disturbed area around the proposed structure shall be graded to direct all runoff to the north.

Sincerely,

Terry R. White, Jr., P.E.
Water Resources Engineer



I certify that the finished floor elevation listed above will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.

Digitally signed by Terry R White
Date: 2021.01.14 14:13:53-05'00'

Terry R. White, Jr., P.E.

1/14/21

Date