



Donald F. Lee & Associates, Inc.

140 NW Ridgewood Avenue Lake City, Florida 32055 PH 386-755-6166 FAX 386-755-6167 email: donald@dfla.com website: www.dfla.com Highway & Route Surveys

- Topographic Surveys
- Land & Subdivision SurveysControl Surveying

Control Survey

Since 1984

DATE: Thursday, May 24, 2018

TO: Columbia County Building Department

CC: Bryan Zecher Construction

FROM: Tim Delbene - Donald F. Lee & Associates

RE: Floor Elevation Check – Lot 73, Oaks of Lake City Phase 2

This is to Certify that elevations were obtained for a residence under construction on the above referenced parcel of land. The results are as follows:

Foundation (stemwall) elevation: 88.52 feet

The record subdivision plat for this development indicates a Minimum Floor Elevation (MFE) for this lot of 85.0 feet.

Elevations are based on NAVD1988 datum.

have withy A. Delbene, PSM ida Reg Cert. No. LS 5594 1000